

嘉義市垃圾焚化廠CEMS煙囪監測系統月報

資料日期 115年4月

文件編號

煙囪編號:

P001

測項	氯化氫	一氧化碳	氮氧化物	二氧化硫	氧氣	不透光率	流速/流率	溫度
日/單位	ppm	ppm	ppm	ppm	%	%	m3/hr	℃
01	6.63	1.19	65.17	4.42	7.25	1.71	24226.67	157.73
02	9.30	1.38	65.42	6.13	7.53	1.70	23701.69	159.78
03	8.68	1.23	64.34	6.30	7.32	1.69	24216.35	161.40
04	9.50	1.37	63.97	7.32	7.24	1.64	24072.51	161.25
05	8.96	1.14	65.07	5.89	7.66	1.71	23919.13	164.17
06	8.40	1.48	65.46	5.81	7.56	1.72	23793.00	160.05
07	6.10	1.38	65.77	2.46	7.85	1.70	23672.54	164.55
08	9.27	1.34	66.95	4.71	7.67	1.65	23845.33	162.07
09	8.68	1.23	66.29	4.74	7.55	1.69	24046.55	162.37
10	9.44	1.23	66.46	4.95	7.51	1.71	24184.77	161.47
11	9.64	1.49	64.71	6.05	7.44	1.71	23866.18	157.85
12	8.74	1.50	64.90	5.50	7.09	1.70	24217.90	160.10
13	7.53	1.62	65.27	4.97	7.22	1.65	24310.24	162.37
14	7.14	2.00	65.18	4.89	7.69	1.64	23539.50	157.69
15	9.50	1.38	65.02	7.71	7.40	1.73	23908.29	159.52
16	9.45	1.47	64.32	8.31	7.47	1.73	23869.62	158.55
17	9.72	1.36	64.14	8.63	7.27	1.68	24354.91	162.45
18	5.30	1.15	67.64	9.94	7.04	1.64	24327.60	158.34
19	8.88	1.55	68.63	7.25	7.54	1.65	23776.72	160.48
20	8.61	1.55	64.87	7.21	7.44	1.75	23739.94	162.72
21	8.01	1.65	64.55	6.01	7.56	1.68	23413.85	165.72
22	9.40	1.58	65.70	7.26	7.40	1.49	23910.87	162.49
23	9.82	1.21	66.27	8.92	7.36	1.46	24027.04	161.82
24	9.00	1.06	67.32	7.99	7.45	1.43	23961.01	160.47
25	8.49	1.35	66.15	9.65	7.50	1.49	23968.06	157.44
26	8.30	1.43	65.29	9.12	7.46	1.48	23855.88	158.65
27	8.66	1.52	66.78	9.54	7.56	1.50	23864.94	156.83
28	8.48	1.47	65.82	8.48	7.61	1.34	23326.47	154.33
29	8.77	1.88	64.28	8.09	7.12	1.08	24666.28	154.53
30	1.06	27.50	36.21	14.75	24.03	1.53	27066.59	85.35
31								
平均值	8.32	2.29	64.60	7.10	7.99	1.61	24055.01	157.75
最大值	9.82	27.50	68.63	14.75	24.03	1.75	27066.59	165.72
最小值	1.06	1.06	36.21	2.46	7.04	1.08	23326.47	85.35
排放標準	<60.00	<150.00	<85.00	<150.00		<10.00		
月排放量	233.53	46.79	2284.09	352.45				