

嘉義市垃圾焚化廠CEMS煙囪監測系統月報

資料日期 115年5月

文件編號

煙囪編號:

P001

測項	氯化氫	一氧化碳	氮氧化物	二氧化硫	氧氣	不透光率	流速/流率	溫度
日/單位	ppm	ppm	ppm	ppm	%	%	m3/hr	℃
01	0.50	0.20	22.69	10.54	25.29	2.00	32616.46	42.41
02	0.62	0.02	25.72	9.03	25.26	1.83	9768.35	37.19
03	0.70	0.77	28.15	7.14	25.27	1.67	1313.97	36.60
04	0.68	0.71	24.07	5.47	25.28	1.53	6167.53	31.08
05	0.28	0.09	24.52	4.63	25.27	1.43	8216.92	25.13
06	0.05	0.00	25.76	4.84	25.26	1.39	8904.79	24.90
07	0.28	0.00	27.10	3.28	25.18	1.90	6916.86	28.33
08	0.49	0.00	26.14	3.16	25.21	1.94	6564.97	28.06
09	0.47	0.00	22.37	3.54	25.34	1.95	6939.14	26.18
10	0.33	0.00	26.89	3.14	25.26	1.95	7126.89	28.47
11	1.36	24.97	30.88	8.95	24.85	2.00	10511.04	36.55
12	8.20	111.67	73.34	16.50	16.37	2.13	20801.82	122.67
13	4.53	4.84	63.49	11.11	7.43	2.70	25419.49	153.56
14	4.72	2.45	65.06	10.29	8.01	2.91	24616.46	156.21
15	5.49	0.71	61.73	9.76	7.63	3.21	25194.18	155.02
16	4.91	0.98	62.96	9.50	7.61	3.56	25494.52	155.82
17	3.65	1.14	65.31	9.55	7.93	3.93	24703.48	154.47
18	0.45	3.98	79.99	8.15	9.21	3.58	22612.98	158.99
19	4.20	1.45	63.23	7.81	6.94	1.65	25660.88	152.28
20	2.33	1.20	63.49	7.59	6.85	1.77	25750.05	151.71
21	1.65	1.01	63.10	8.84	7.00	1.89	25688.13	153.26
22	5.60	0.75	65.63	8.48	6.83	1.97	25746.77	152.90
23	8.09	0.64	66.35	8.34	6.59	2.10	25792.07	150.94
24	7.70	0.24	68.26	8.42	6.70	2.45	26069.74	151.80
25	4.72	1.63	65.30	9.06	7.00	3.19	25314.98	153.24
26	5.80	1.93	60.74	7.15	7.24	3.44	24443.75	156.33
27	4.71	2.66	59.18	7.24	8.21	1.58	22842.98	154.95
28	7.16	2.68	58.80	4.70	7.56	1.57	28014.36	152.76
29	5.19	2.87	55.50	4.43	7.05	1.51	24539.93	154.94
30	8.40	3.43	59.25	5.53	7.10	1.49	24428.30	152.37
31	3.53	2.75	57.65	1.62	7.20	1.60	24510.50	156.02
平均值	3.44	5.67	50.41	7.35	14.00	2.19	19441.69	109.52
最大值	8.40	111.67	79.99	16.50	25.34	3.93	32616.46	158.99
最小值	0.05	0.00	22.37	1.62	6.59	1.39	1313.97	24.90
排放標準	<60.00	<150.00	<85.00	<150.00		<10.00		
月排放量	100.17	105.06	1661.35	329.13				