

嘉義市垃圾焚化廠CEMS煙囪監測系統月報

資料日期 115年5月

文件編號

煙囪編號:

P002

測項	氮化氫	一氧化碳	氮氧化物	二氧化硫	氧氣	不透光率	流速/流率	溫度
日/單位	ppm	ppm	ppm	ppm	%	%	m3/hr	℃
01	0.41	0.83	22.47	5.88	25.79	3.41	3894.83	39.95
02	0.19	0.01	22.53	4.04	25.90	3.62	2935.21	39.32
03	0.04	0.01	22.52	3.58	25.96	3.70	2989.97	40.93
04	0.28	0.08	20.38	3.63	25.96	3.90	3130.73	37.55
05	0.37	0.11	21.64	3.69	25.97	4.07	4388.12	32.10
06	0.11	0.00	22.60	3.93	26.00	4.16	3009.00	31.03
07	0.81	0.00	24.22	2.80	25.16	2.31	2961.32	34.94
08	1.00	0.03	22.89	3.05	25.14	2.49	2996.52	34.87
09	1.16	0.04	19.10	3.69	25.25	2.68	3369.70	32.41
10	10.30	25.59	159.44	3.23	9.18	2.34	23701.19	154.31
11	9.75	3.68	70.91	4.72	7.93	2.49	24270.89	154.56
12	7.30	5.08	71.20	9.05	7.64	2.63	24174.10	153.50
13	9.29	3.71	66.35	11.51	7.54	2.73	24204.22	156.12
14	10.97	2.78	65.85	10.84	8.13	2.33	23756.89	158.86
15	11.00	1.89	64.25	9.65	7.82	2.02	24354.68	159.44
16	12.58	1.16	66.05	9.36	8.13	2.09	23876.42	161.32
17	13.34	1.45	67.86	8.00	8.56	2.14	23906.74	162.17
18	13.89	3.85	66.29	5.81	8.95	2.18	22914.99	166.97
19	24.14	7.17	77.43	10.25	8.71	2.22	22456.96	154.80
20	11.27	1.03	64.77	11.37	8.00	2.27	23611.31	154.30
21	11.60	1.31	65.97	9.98	8.44	2.31	22994.90	155.89
22	11.79	1.04	65.12	8.75	8.18	2.36	23438.81	157.85
23	12.20	1.17	66.21	11.25	8.40	2.42	23109.19	156.47
24	11.73	0.92	65.53	13.04	8.33	2.46	23339.84	156.76
25	11.84	1.66	68.30	10.56	8.98	2.50	22585.02	157.71
26	11.55	1.61	64.66	6.68	9.18	2.26	21800.01	157.40
27	12.46	2.60	63.23	8.11	9.69	1.68	20643.18	157.71
28	12.78	2.80	64.02	6.27	9.48	1.74	20430.15	157.41
29	11.86	3.77	61.31	6.35	9.13	1.81	20992.33	157.85
30	12.31	3.99	59.72	6.72	8.84	1.85	20999.95	158.10
31	10.54	4.68	64.16	3.41	9.66	1.90	20414.53	161.57
平均值	8.67	2.71	56.35	7.07	13.55	2.55	17150.05	122.39
最大值	24.14	25.59	159.44	13.04	26.00	4.16	24354.68	166.97
最小值	0.04	0.00	19.10	2.80	7.54	1.68	2935.21	31.03
排放標準	<60.00	<150.00	<85.00	<150.00		<10.00		
月排放量	228.67	45.36	1625.64	296.01				