

嘉義市垃圾焚化廠CEMS煙囪監測系統月報

資料日期 115年6月

文件編號

煙囪編號:

P001

測項	氯化氫	一氧化碳	氮氧化物	二氧化硫	氧氣	不透光率	流速/流率	溫度
日/單位	ppm	ppm	ppm	ppm	%	%	m3/hr	°C
01	7.08	3.06	58.51	4.09	7.18	1.74	24408.85	154.49
02	4.39	2.88	60.65	2.82	6.92	1.91	24399.47	154.81
03	8.52	4.73	59.42	4.35	6.92	2.00	24387.11	152.20
04	8.98	2.52	60.19	2.49	7.00	2.23	24865.93	154.56
05	9.15	2.41	58.98	0.67	6.80	2.52	25451.54	157.20
06	10.27	2.65	58.61	1.40	6.60	2.57	25326.32	154.41
07	10.39	2.30	58.49	1.59	6.70	3.03	25156.59	155.95
08	8.65	4.32	62.90	1.46	7.24	3.31	24280.53	160.20
09	7.43	2.76	63.98	2.25	7.20	2.09	24866.68	156.69
10	6.35	2.50	64.16	2.37	6.88	1.16	25385.21	159.63
11	5.37	3.79	67.90	3.78	7.50	1.19	24364.62	159.45
12	8.45	2.96	65.96	4.52	7.32	1.28	25515.39	156.07
13	10.57	2.31	65.18	4.83	7.12	1.77	25549.14	156.20
14	10.63	2.61	65.35	5.21	7.30	1.97	25030.85	154.75
15	6.85	2.98	66.08	4.85	7.06	1.66	25285.26	154.64
16	4.98	3.08	63.98	4.54	6.95	1.18	25694.20	160.62
17	8.15	2.84	64.55	6.00	7.00	1.15	25121.53	155.93
18	6.77	2.80	65.83	5.45	7.24	1.18	24966.05	156.38
19	7.15	2.36	63.59	5.56	6.80	1.08	25241.26	158.80
20	8.52	2.29	65.21	4.36	6.60	0.90	25654.29	156.58
21	8.72	2.92	67.50	4.55	6.91	0.86	24936.25	160.17
22	9.66	2.15	65.40	6.26	6.86	0.90	25779.98	157.92
23	10.75	2.63	64.08	4.60	6.72	0.96	26220.08	154.47
24	9.21	3.32	62.11	4.32	6.84	1.26	25152.61	154.89
25	9.42	2.04	61.70	6.68	6.57	1.51	25547.07	161.87
26	7.15	2.75	63.31	3.59	6.63	1.84	25509.41	167.61
27	5.56	3.07	64.80	3.13	6.92	2.11	24733.23	163.47
28	6.13	2.39	66.29	3.81	6.83	2.31	25324.92	170.50
29	6.00	2.79	65.77	5.52	6.87	2.47	25278.23	172.34
30	5.12	1.86	65.56	3.78	7.05	2.58	24889.77	159.98
31								
平均值	7.88	2.80	63.53	3.96	6.95	1.76	25144.08	158.43
最大值	10.75	4.73	67.90	6.68	7.50	3.31	26220.08	172.34
最小值	4.39	1.86	58.49	0.67	6.57	0.86	24280.53	152.20
排放標準	<60.00	<150.00	<85.00	<150.00		<10.00		
月排放量	235.57	63.33	2353.95	207.99				