

嘉義市垃圾焚化廠CEMS煙囪監測系統月報

資料日期 115年6月

文件編號

煙囪編號:

P002

測項	氯化氫	一氧化碳	氮氧化物	二氧化硫	氧氣	不透光率	流速/流率	溫度
日/單位	ppm	ppm	ppm	ppm	%	%	m3/hr	°C
01	12.46	2.79	63.42	6.37	9.66	1.94	20304.12	158.00
02	11.28	3.38	61.97	6.82	8.99	2.02	21089.60	158.20
03	12.42	3.20	59.37	5.34	8.68	2.10	21845.42	157.40
04	12.91	2.05	59.36	3.91	8.38	2.14	22681.42	157.13
05	11.29	2.76	61.74	1.78	8.51	2.18	22883.71	161.85
06	12.31	2.53	59.49	3.21	8.04	2.25	22670.40	157.36
07	12.13	4.03	60.15	3.12	8.06	2.28	22823.84	159.30
08	11.69	3.61	62.27	2.64	8.84	2.30	21887.20	163.06
09	11.69	3.48	66.99	2.40	9.40	2.38	21585.35	159.42
10	11.08	2.92	66.80	1.47	9.06	2.44	21705.06	161.66
11	12.46	3.25	65.87	3.01	9.06	2.47	21477.42	162.06
12	13.17	2.95	67.56	3.60	9.08	2.50	22052.88	162.07
13	13.37	3.00	64.84	3.74	8.78	2.54	21955.03	159.97
14	14.16	2.49	65.93	3.82	8.45	2.55	21960.25	158.16
15	13.66	3.56	67.43	4.54	8.87	2.23	21721.50	159.23
16	13.79	2.74	65.68	5.18	9.15	1.75	21152.63	163.73
17	12.26	2.79	68.41	4.14	8.98	1.83	21538.66	161.63
18	11.76	2.99	69.42	4.20	9.39	1.90	20685.12	158.68
19	11.36	1.95	66.84	5.42	9.01	1.94	21093.58	159.94
20	13.25	2.19	66.47	6.56	9.12	1.98	21258.88	158.60
21	11.45	2.30	64.83	5.52	9.00	2.04	21190.25	161.12
22	12.45	3.71	67.48	4.64	9.06	2.07	21037.40	158.30
23	11.87	3.80	69.12	1.91	8.70	2.08	21674.66	157.66
24	11.48	1.65	68.10	3.45	8.37	2.12	21971.29	158.02
25	10.49	2.48	69.84	4.14	9.25	2.14	20830.71	167.33
26	8.52	3.27	68.48	1.48	9.14	2.18	21031.23	172.21
27	9.58	2.73	68.93	2.58	9.21	2.24	20635.69	171.77
28	10.46	1.91	69.84	3.65	8.64	2.30	21503.25	171.86
29	9.98	8.40	68.64	2.09	9.22	2.35	20934.13	171.73
30	9.53	0.35	63.71	2.25	8.10	2.35	21863.78	162.39
31								
平均值	11.81	2.98	65.63	3.77	8.87	2.19	21568.15	161.66
最大值	14.16	8.40	69.84	6.82	9.66	2.55	22883.71	172.21
最小值	8.52	0.35	59.36	1.47	8.04	1.75	20304.12	157.13
排放標準	<60.00	<150.00	<85.00	<150.00		<10.00		
月排放量	299.61	57.18	2082.99	167.98				