

嘉義市垃圾焚化廠CEMS煙囪監測系統月報

資料日期 115年7月

文件編號

煙囪編號:

P001

測項	氯化氫	一氧化碳	氮氧化物	二氧化硫	氧氣	不透光率	流速/流率	溫度
日/單位	ppm	ppm	ppm	ppm	%	%	m3/hr	°C
01	3.30	1.85	64.97	1.52	7.03	2.73	25154.38	153.91
02	4.34	1.93	64.03	1.93	6.94	2.92	25865.62	152.65
03	7.36	2.41	65.30	2.78	6.97	2.68	25332.10	153.67
04	7.33	2.23	65.37	4.38	7.05	2.46	24917.61	155.17
05	4.89	2.14	64.45	3.79	6.98	2.51	24975.77	154.92
06	6.76	2.18	62.66	3.07	6.72	2.76	25016.04	152.82
07	7.54	1.88	66.88	3.51	7.04	2.92	25112.52	154.37
08	6.15	2.07	64.04	5.38	6.73	2.81	25469.53	153.91
09	5.77	1.98	63.89	5.66	6.80	2.78	25179.03	153.74
10	5.92	2.71	65.01	5.24	7.26	2.98	24830.14	154.41
11	7.96	2.53	64.59	6.73	6.98	3.03	25771.31	155.67
12	6.84	2.50	64.88	4.50	7.00	3.73	25335.09	162.01
13	6.23	2.24	66.93	5.70	7.21	2.26	24681.89	159.17
14	4.60	1.78	66.46	3.78	7.52	0.90	23893.46	159.24
15	3.10	4.11	67.92	6.90	7.61	0.96	24147.43	155.44
16	0.19	4.54	65.44	4.08	7.88	1.13	23265.55	152.70
17	0.20	2.84	65.35	2.06	7.72	1.13	23893.91	150.37
18	0.76	3.05	62.93	1.17	7.32	1.30	24227.15	150.16
19	1.41	2.77	64.15	1.04	7.07	1.39	24644.19	150.28
20	5.37	2.20	67.06	3.81	7.76	1.49	23891.83	150.72
21	6.47	2.48	66.19	4.77	7.84	1.51	23695.38	151.02
22	6.21	3.24	66.25	6.69	8.06	1.57	23392.93	152.87
23	6.69	3.60	64.09	7.83	7.70	1.71	23805.85	153.76
24	2.02	4.48	60.28	3.72	7.44	2.07	24029.20	150.92
25	8.10	5.41	62.10	5.26	7.77	2.33	23546.85	149.99
26	7.34	5.06	64.15	5.33	8.03	2.54	23411.73	152.50
27	7.01	6.24	64.97	5.14	8.18	1.57	22860.55	157.24
28	4.66	4.68	61.49	3.55	7.56	0.85	23926.37	152.18
29	3.23	4.83	61.85	3.42	7.51	2.91	23943.61	149.94
30	6.40	4.27	66.59	4.24	7.35	3.82	24292.51	149.96
31	9.20	4.32	63.71	3.64	7.59	2.24	23843.75	149.94
平均值	5.27	3.18	64.64	4.21	7.37	2.19	24398.49	153.41
最大值	9.20	6.24	67.92	7.83	8.18	3.82	25865.62	162.01
最小值	0.19	1.78	60.28	1.04	6.72	0.85	22860.55	149.94
排放標準	<60.00	<150.00	<85.00	<150.00		<10.00		
月排放量	156.50	71.54	2408.33	218.94				