

嘉義市垃圾焚化廠CEMS煙囪監測系統月報

資料日期 115年7月

文件編號

煙囪編號:

P002

測項	氯化氫	一氧化碳	氮氧化物	二氧化硫	氧氣	不透光率	流速/流率	溫度
日/單位	ppm	ppm	ppm	ppm	%	%	m3/hr	°C
01	10.57	2.04	67.30	2.42	8.61	2.37	21567.40	157.73
02	10.61	2.12	66.29	2.46	8.79	2.38	21511.78	159.47
03	10.80	1.88	66.87	2.51	8.95	2.40	21437.00	158.91
04	9.73	2.00	64.65	2.94	8.61	2.42	21394.60	157.95
05	8.75	1.78	65.86	4.11	8.20	2.43	21917.06	159.64
06	11.31	1.60	66.38	5.52	8.45	2.45	21521.81	157.41
07	10.01	2.40	65.82	7.67	8.76	2.47	21544.93	160.86
08	11.11	2.87	65.15	10.29	8.63	2.51	21629.82	161.19
09	10.82	2.74	64.63	9.79	8.53	2.51	21454.55	160.18
10	11.17	2.89	64.67	8.93	8.54	2.53	21735.85	160.54
11	12.08	3.79	67.07	7.88	9.23	2.53	21310.79	159.63
12	10.90	1.15	65.46	6.54	8.86	2.70	21547.52	162.46
13	10.83	0.60	66.75	3.95	8.59	2.27	21793.73	160.03
14	10.33	1.10	66.29	0.33	8.53	1.74	21725.40	161.55
15	8.57	2.17	67.13	2.34	9.05	1.78	21359.47	157.84
16	7.16	2.34	66.16	0.56	9.06	1.83	20730.91	155.55
17	4.91	0.78	65.62	0.14	8.98	1.84	21245.07	153.42
18	6.34	0.52	67.30	0.05	8.53	1.88	21885.18	153.32
19	6.35	1.08	66.20	0.14	8.51	1.92	21815.39	153.43
20	7.89	0.63	67.36	0.35	9.15	1.97	20880.80	153.30
21	8.77	1.64	65.58	1.46	8.77	2.00	21325.97	153.16
22	9.27	3.25	66.33	2.31	8.61	2.05	21556.68	153.40
23	9.61	3.38	65.57	1.47	8.48	2.06	21545.69	153.26
24	6.70	3.52	65.21	2.79	8.41	2.06	21538.95	153.94
25	9.91	3.32	66.28	5.05	8.61	2.08	21291.55	153.39
26	9.88	3.72	68.19	3.45	8.77	2.08	21243.12	157.18
27	8.64	5.01	69.85	8.02	9.80	1.86	20056.01	164.95
28	5.48	4.56	62.82	10.85	8.62	1.54	21575.97	155.04
29	9.34	6.39	64.85	9.07	8.97	1.60	21164.50	153.32
30	8.02	5.01	63.74	8.24	8.77	1.63	21422.15	153.92
31	10.26	4.54	61.19	8.35	8.52	1.66	21552.95	153.44
平均值	9.23	2.61	65.89	4.52	8.74	2.11	21428.47	157.08
最大值	12.08	6.39	69.85	10.85	9.80	2.70	21917.06	164.95
最小值	4.91	0.52	61.19	0.05	8.20	1.54	20056.01	153.16
排放標準	<60.00	<150.00	<85.00	<150.00		<10.00		
月排放量	240.22	51.66	2153.36	206.01				