

嘉義市垃圾焚化廠CEMS煙囪監測系統月報

資料日期 115年8月

文件編號

煙囪編號:

P001

測項	氯化氫	一氧化碳	氮氧化物	二氧化硫	氧氣	不透光率	流速/流率	溫度
日/單位	ppm	ppm	ppm	ppm	%	%	m3/hr	°C
01	6.43	4.65	60.63	2.10	7.73	0.00	23709.43	149.95
02	7.30	4.55	60.51	3.26	7.59	0.00	23799.79	150.33
03	8.37	6.23	61.35	3.86	7.92	0.18	23490.00	150.43
04	9.01	3.94	61.08	4.10	7.85	0.31	23708.86	150.75
05	10.01	3.97	61.63	3.61	7.92	0.92	23567.42	150.03
06	9.28	3.51	58.91	4.46	7.81	1.42	24013.68	150.40
07	8.73	3.15	58.72	5.67	7.77	1.38	24034.49	150.29
08	9.66	3.14	58.80	5.98	7.57	1.27	24032.48	149.75
09	9.09	3.21	58.59	6.82	7.43	1.20	24555.23	150.33
10	9.81	2.79	59.21	5.97	7.55	1.19	24144.21	150.35
11	10.00	2.56	58.38	4.89	7.49	1.24	24481.95	151.24
12	9.28	2.98	59.25	4.69	7.26	1.29	24920.92	150.57
13	9.88	3.17	60.89	3.30	7.18	1.27	25003.02	150.62
14	9.81	3.66	59.50	3.13	7.12	1.23	24804.21	150.36
15	10.59	3.36	60.38	3.21	7.06	1.25	25054.65	149.77
16	11.64	3.28	62.08	4.20	7.28	1.28	25254.49	150.72
17	10.15	3.60	63.42	4.69	7.38	1.29	24924.58	150.44
18	10.88	3.29	64.61	3.93	7.35	1.30	25243.95	152.01
19	10.07	3.26	64.16	3.43	7.52	1.28	24576.20	151.13
20	9.97	3.70	65.79	3.15	7.89	1.28	24352.67	150.77
21	9.60	2.92	65.65	3.93	7.68	1.27	24492.74	150.67
22	9.20	3.05	64.16	4.79	7.62	1.28	24412.41	150.06
23	8.13	2.94	65.11	3.65	7.66	1.35	24921.13	151.39
24	8.26	3.41	64.52	3.72	7.92	1.66	24601.78	152.07
25	6.55	3.05	63.66	2.38	7.56	2.00	24976.58	151.05
26	9.50	3.23	63.99	3.70	7.52	2.75	24808.66	151.18
27	9.67	2.97	63.10	4.68	7.36	3.47	25039.14	150.92
28	6.46	2.84	61.92	3.89	7.32	3.10	24774.91	150.93
29	9.01	2.99	62.84	4.22	7.30	2.64	25058.53	151.46
30	8.44	3.06	62.15	4.37	7.48	2.78	24839.67	151.80
31	8.88	2.93	64.05	3.92	7.67	1.86	24534.17	152.15
平均值	9.15	3.40	61.90	4.12	7.54	1.44	24520.39	150.77
最大值	11.64	6.23	65.79	6.82	7.92	3.47	25254.49	152.15
最小值	6.43	2.56	58.38	2.10	7.06	0.00	23490.00	149.75
排放標準	<60.00	<150.00	<85.00	<150.00		<10.00		
月排放量	272.03	77.56	2314.21	214.71				