

嘉義市垃圾焚化廠CEMS煙囪監測系統月報

資料日期 115年8月

文件編號

煙囪編號:

P002

測項	氯化氫	一氧化碳	氮氧化物	二氧化硫	氧氣	不透光率	流速/流率	溫度
日/單位	ppm	ppm	ppm	ppm	%	%	m3/hr	°C
01	7.23	4.81	57.84	7.72	8.35	1.71	21622.25	153.11
02	8.25	4.45	55.75	8.76	7.94	1.75	21990.07	153.32
03	7.81	4.43	56.78	7.52	8.44	1.77	21363.73	152.92
04	9.60	4.51	57.26	8.28	8.43	1.80	21711.51	153.44
05	9.19	4.38	55.26	9.32	7.83	1.60	22580.09	153.08
06	9.37	4.09	54.63	9.67	7.68	1.43	22507.50	152.83
07	9.66	4.78	57.39	8.95	8.28	1.46	21994.92	153.95
08	10.18	4.72	57.32	9.06	8.46	1.50	21555.86	153.25
09	9.99	4.29	55.71	8.95	7.94	1.52	22430.88	153.15
10	9.85	4.40	55.24	9.38	7.94	1.56	22246.51	153.03
11	10.06	5.01	55.82	9.30	8.30	1.46	21884.47	153.54
12	10.18	3.57	55.73	7.94	7.89	1.40	22764.09	153.51
13	12.58	3.10	53.25	7.19	7.77	1.47	22576.20	153.07
14	9.95	2.89	52.39	7.39	7.34	1.51	23045.49	153.78
15	11.35	3.11	57.68	7.77	7.82	1.55	22934.43	153.84
16	11.93	3.54	57.91	8.26	7.93	1.59	23044.64	155.13
17	11.91	3.33	59.07	8.50	8.30	1.62	22327.20	155.82
18	11.51	3.50	60.44	7.57	8.27	1.64	22464.67	157.04
19	10.34	3.38	57.33	7.86	7.84	1.69	22880.25	155.26
20	10.25	3.27	59.22	8.22	8.13	1.72	22223.16	154.03
21	9.79	3.39	60.09	7.84	8.38	1.70	22268.74	154.28
22	9.95	4.21	62.44	7.64	8.70	1.68	22150.71	157.15
23	9.09	4.19	60.88	7.63	8.35	1.70	22715.27	159.40
24	5.63	4.02	64.12	6.33	9.01	1.73	21560.07	158.66
25	7.28	5.58	62.25	6.93	9.04	1.73	21542.97	158.05
26	9.91	3.51	59.85	7.55	8.22	1.77	22600.68	157.45
27	10.62	3.25	61.57	7.78	8.71	1.80	22178.26	156.83
28	9.33	3.88	59.39	7.30	8.34	1.85	22502.55	157.29
29	10.30	3.78	62.34	7.20	8.45	1.86	22551.00	158.25
30	10.19	3.87	61.66	7.45	8.20	1.89	22849.51	157.23
31	10.36	4.39	62.67	7.35	8.70	1.89	22343.86	158.70
平均值	9.79	3.99	58.36	8.02	8.23	1.66	22303.60	155.17
最大值	12.58	5.58	64.12	9.67	9.04	1.89	23045.49	159.40
最小值	5.63	2.89	52.39	6.33	7.34	1.40	21363.73	152.83
排放標準	<60.00	<150.00	<85.00	<150.00		<10.00		
月排放量	265.54	82.19	1982.82	380.69				