

嘉義市垃圾焚化廠CEMS煙囪監測系統月報

資料日期 2025/01

文件編號

煙囪編號:

P001

測項	氯化氫	一氧化碳	氮氧化物	二氧化硫	氧氣	不透光率	流速/流率	溫度
日/單位	ppm	ppm	ppm	ppm	%	%	m3/hr	°C
01	5.27	4.11	62.74	10.86	7.53	2.78	23909.14	155.10
02	7.70	3.25	61.86	8.29	7.29	2.77	23982.52	153.97
03	10.57	2.96	64.42	9.44	7.42	2.79	23950.74	157.13
04	6.56	3.48	66.97	10.65	7.62	2.78	23719.25	156.93
05	7.81	4.16	63.78	8.24	7.10	2.76	24170.90	154.55
06	6.96	3.51	65.39	8.96	7.01	2.75	18683.40	157.10
07	5.52	3.99	68.21	7.50	7.37	2.72	23921.84	154.48
08	5.27	6.76	64.88	10.50	7.14	2.70	24264.25	152.87
09	5.99	3.61	62.22	9.72	6.97	2.71	24473.87	156.57
10	8.21	3.01	66.36	10.19	7.84	2.72	23605.42	155.74
11	2.80	3.97	64.94	11.25	7.98	2.69	23077.35	153.73
12	1.14	3.34	64.54	13.43	7.50	2.67	23565.78	155.52
13	3.43	4.53	62.79	11.12	7.24	2.61	23811.51	153.86
14	3.48	3.71	64.62	8.65	7.76	2.65	23188.80	156.37
15	5.58	3.54	62.93	6.15	6.97	2.58	24561.35	155.51
16	10.96	3.63	62.35	5.78	7.08	2.56	23725.92	154.79
17	9.99	2.69	62.17	5.36	6.94	2.51	24018.49	153.27
18	12.19	5.11	60.97	7.93	7.03	2.49	23835.86	152.78
19	12.78	4.17	64.55	8.35	7.45	2.62	23255.32	157.84
20	10.29	4.15	63.73	4.94	7.24	2.59	23406.11	155.40
21	11.96	4.93	64.74	5.59	7.64	2.60	23210.87	154.64
22	12.54	5.18	63.42	9.46	7.46	2.60	23135.98	154.89
23	22.89	4.02	64.64	9.87	7.64	2.59	22941.34	154.26
24	12.29	4.44	65.35	7.89	7.78	2.58	22995.38	151.48
25	12.14	5.93	64.87	8.59	7.93	2.54	22653.27	147.51
26	12.67	5.72	63.72	7.08	7.79	2.54	22752.76	148.90
27	13.45	7.34	62.85	7.83	7.71	2.51	22858.99	149.59
28	11.50	4.04	63.38	6.35	7.33	2.51	23494.30	154.43
29	11.25	3.81	62.12	6.84	7.13	2.51	23659.33	154.19
30	11.82	4.11	63.22	6.92	7.17	2.53	23816.61	155.38
31	11.36	3.36	65.77	5.93	7.71	2.57	23404.03	157.25
平均值	9.24	4.21	64.02	8.38	7.41	2.63	23420.99	154.39
最大值	22.89	7.34	68.21	13.43	7.98	2.79	24561.35	157.84
最小值	1.14	2.69	60.97	4.94	6.94	2.49	18683.40	147.51
排放標準	<60.00	<150.00	<220.00	<150.00		<10.00		
月排放量	261.49	91.69	2285.25	416.94	0.00	0.00	0.00	0.00