

嘉義市垃圾焚化廠CEMS煙囪監測系統月報

資料日期 2025/02

文件編號

煙囪編號:

P001

測項	氯化氫	一氧化碳	氮氧化物	二氧化硫	氧氣	不透光率	流速/流率	溫度
日/單位	ppm	ppm	ppm	ppm	%	%	m3/hr	℃
01	10.68	3.09	65.49	6.12	7.73	2.58	23408.86	156.48
02	10.58	2.97	66.07	5.57	7.65	2.57	23226.08	156.50
03	8.40	2.58	65.58	6.79	7.65	2.56	23214.91	157.72
04	8.73	2.69	65.89	7.65	7.82	2.54	23230.43	159.52
05	11.17	3.76	69.27	4.59	8.32	2.56	22880.58	169.00
06	7.69	4.94	64.41	5.26	8.12	2.52	22419.57	158.78
07	5.70	4.43	59.88	5.94	7.28	2.51	24479.53	159.58
08	9.36	2.49	59.98	5.76	6.99	2.51	24639.94	160.04
09	9.58	2.75	63.33	8.70	7.04	2.54	24389.45	158.66
10	8.44	2.45	63.08	6.18	6.88	2.55	24586.38	157.76
11	8.55	2.79	63.41	4.22	6.85	2.53	24812.29	157.24
12	9.53	3.25	64.10	6.26	6.88	2.58	24404.99	157.34
13	8.20	3.00	64.27	6.00	6.88	2.63	24628.01	160.42
14	5.73	2.93	63.87	2.06	6.87	2.65	25195.88	161.78
15	6.99	2.86	64.71	3.96	7.00	2.67	25053.79	161.32
16	8.38	2.76	63.91	6.28	6.84	2.68	24966.78	160.86
17	6.57	3.26	63.25	3.82	6.77	2.69	25015.17	161.94
18	6.46	3.08	66.14	2.90	7.00	2.68	24683.01	159.95
19	8.93	3.05	64.38	7.94	7.16	2.67	24342.92	159.19
20	11.04	2.30	61.42	8.02	7.15	2.66	24188.79	158.92
21	11.98	2.16	60.53	6.00	7.54	2.67	23879.71	158.21
22	10.20	1.85	63.74	5.06	7.61	2.73	23876.31	155.55
23	10.45	1.90	64.31	6.18	7.26	2.74	24544.73	159.00
24	9.11	1.62	63.81	5.52	7.01	2.70	24466.79	158.06
25	9.66	1.64	68.33	5.03	7.66	2.69	23582.89	158.06
26	8.34	2.63	62.61	7.18	8.35	2.96	22352.79	154.63
27	8.86	3.49	64.58	11.39	7.57	2.87	23779.39	154.29
28	9.78	2.11	64.55	11.50	7.56	2.94	24170.48	157.82
29								
30								
31								
平均值	8.90	2.82	64.10	6.14	7.34	2.65	24086.44	158.88
最大值	11.98	4.94	69.27	11.50	8.35	2.96	25195.88	169.00
最小值	5.70	1.62	59.88	2.06	6.77	2.51	22352.79	154.29
排放標準	<60.00	<150.00	<220.00	<150.00		<10.00		
月排放量	234.16	57.14	2127.01	284.22	0.00	0.00	0.00	0.00