

嘉義市垃圾焚化廠CEMS煙囪監測系統月報

資料日期 2025/02

文件編號

煙囪編號:

P002

測項	氯化氫	一氧化碳	氮氧化物	二氧化硫	氧氣	不透光率	流速/流率	溫度
日/單位	ppm	ppm	ppm	ppm	%	%	m3/hr	℃
01	7.08	6.22	61.77	11.43	7.53	4.65	22556.67	158.60
02	7.39	5.07	60.45	10.17	7.60	4.70	22352.20	157.88
03	3.08	10.51	59.45	9.11	7.89	4.48	22143.35	158.61
04	1.39	16.00	53.95	8.77	8.11	4.21	20977.08	154.38
05	0.00	230.90	44.66	13.59	15.79	4.24	12778.06	132.50
06	0.02	56.68	16.65	9.06	25.25	4.34	12194.46	76.97
07	0.00	29.49	26.63	7.32	24.15	4.34	12103.91	74.78
08	3.86	10.28	67.19	11.99	8.19	4.44	22565.02	163.13
09	5.97	2.78	62.69	10.66	6.45	4.31	25601.81	158.50
10	6.77	2.63	61.66	9.95	6.39	2.29	24630.07	157.71
11	8.38	2.93	63.99	9.82	6.63	2.33	24228.09	157.65
12	9.67	4.36	64.93	9.30	6.72	2.41	24085.81	158.22
13	6.74	4.03	65.53	8.33	7.22	2.44	24039.61	158.72
14	6.60	3.02	64.12	8.23	7.14	2.53	24310.88	158.96
15	8.12	2.94	65.34	8.88	7.35	2.53	23580.35	159.13
16	8.71	2.53	64.94	9.10	6.89	2.56	24306.60	159.53
17	7.15	2.16	64.72	8.15	6.88	2.61	23229.89	159.30
18	4.46	3.21	58.52	7.86	6.66	2.64	24901.49	159.78
19	9.63	2.16	54.97	8.13	6.63	2.68	24660.03	158.78
20	10.27	2.27	56.08	7.55	6.63	2.72	24959.09	159.23
21	8.67	2.84	56.76	8.29	6.84	2.68	25280.01	162.07
22	8.95	3.03	62.39	9.39	7.44	2.54	24020.63	160.45
23	10.87	2.97	64.39	9.89	7.45	2.49	24089.29	161.01
24	8.82	2.85	62.71	8.79	7.35	2.50	24090.41	162.74
25	7.45	3.41	63.24	10.78	7.34	2.57	24040.38	162.24
26	5.13	3.52	61.83	11.04	8.50	2.73	22578.80	158.72
27	8.08	2.77	63.65	11.50	7.36	2.54	23478.49	158.17
28	8.21	3.33	63.54	10.55	7.79	2.72	23849.77	160.04
29								
30								
31								
平均值	6.48	15.17	58.46	9.56	8.79	3.15	22558.29	152.42
最大值	10.87	230.90	67.19	13.59	25.25	4.70	25601.81	163.13
最小值	0.00	2.16	16.65	7.32	6.39	2.29	12103.91	74.78
排放標準	<60.00	<150.00	<220.00	<150.00		<10.00		
月排放量	170.69	177.34	1862.59	410.86	0.00	0.00	0.00	0.00