

嘉義市垃圾焚化廠CEMS煙囪監測系統月報

資料日期 2025/03

文件編號

煙囪編號:

P001

測項	氯化氫	一氧化碳	氮氧化物	二氧化硫	氧氣	不透光率	流速/流率	溫度
日/單位	ppm	ppm	ppm	ppm	%	%	m3/hr	℃
01	9.41	2.10	64.82	11.86	7.49	2.88	24154.61	158.55
02	8.96	2.15	64.45	11.39	7.49	2.80	24345.45	159.73
03	8.06	2.03	65.07	11.28	7.55	2.81	23929.59	160.50
04	8.17	2.16	63.39	10.46	7.38	2.80	24458.41	160.73
05	10.86	2.11	65.23	11.65	7.64	2.79	24211.52	155.95
06	8.84	1.95	65.24	12.21	7.62	2.77	24046.37	154.64
07	8.45	2.27	65.12	11.91	7.79	2.78	23917.66	158.73
08	8.68	2.69	63.90	13.28	7.68	2.72	23370.06	154.07
09	9.05	2.23	64.99	12.96	7.77	2.77	23533.95	156.54
10	8.84	2.09	62.84	12.77	7.47	2.72	23436.82	150.86
11	5.63	1.91	63.84	9.52	7.44	2.77	23886.76	156.32
12	9.10	2.20	64.01	12.82	7.44	2.78	23553.92	156.01
13	7.46	3.22	62.13	13.56	7.21	2.75	23888.23	151.97
14	8.28	2.08	64.56	13.43	7.70	2.75	23517.65	154.72
15	5.62	2.41	64.14	11.84	7.61	2.73	23440.77	151.71
16	6.61	2.00	64.83	11.90	7.83	2.73	23423.68	154.35
17	6.05	2.27	63.90	12.44	7.85	2.74	23545.90	152.43
18	7.26	1.81	63.41	12.68	7.46	2.70	24514.37	155.36
19	7.40	1.85	61.16	13.06	7.23	2.74	24825.95	156.81
20	8.16	1.83	62.70	14.00	7.58	2.75	24164.44	153.83
21	9.41	1.77	64.31	12.80	7.45	2.76	24375.87	154.88
22	8.91	1.83	64.90	13.40	7.49	2.79	24495.54	153.49
23	7.78	1.60	64.81	13.24	7.45	2.80	24675.54	155.38
24	7.72	2.01	61.60	12.91	6.85	2.77	24802.67	152.11
25	7.05	1.78	61.59	11.31	6.88	2.80	24953.89	156.68
26	8.15	2.00	63.48	11.91	7.29	2.79	24545.42	155.97
27	6.17	1.60	63.65	10.11	7.16	2.84	24912.43	158.85
28	6.04	1.43	62.96	9.72	6.88	2.82	25170.85	157.71
29	7.19	1.52	63.86	10.83	7.10	2.79	24725.54	157.24
30	6.25	1.38	63.18	10.33	6.91	2.76	24920.39	156.54
31	5.98	1.81	62.59	10.29	6.85	2.75	24927.01	155.11
平均值	7.79	2.00	63.76	12.00	7.40	2.77	24215.20	155.73
最大值	10.86	3.22	65.24	14.00	7.85	2.88	25170.85	160.73
最小值	5.62	1.38	61.16	9.52	6.85	2.70	23370.06	150.86
排放標準	<60.00	<150.00	<220.00	<150.00		<10.00		
月排放量	228.62	45.16	2354.08	617.70	0.00	0.00	0.00	0.00