

嘉義市垃圾焚化廠CEMS煙囪監測系統月報

資料日期 2025/03

文件編號

煙囪編號:

P002

測項	氯化氫	一氧化碳	氮氧化物	二氧化硫	氧氣	不透光率	流速/流率	溫度
日/單位	ppm	ppm	ppm	ppm	%	%	m3/hr	℃
01	8.59	3.07	61.27	11.54	7.19	2.66	24362.29	160.12
02	8.31	4.50	63.45	10.64	7.46	2.74	24356.08	163.58
03	7.70	3.05	63.86	9.50	7.47	2.72	23949.03	163.06
04	8.56	3.06	61.98	10.24	7.45	2.77	24250.21	162.23
05	8.96	3.18	63.49	12.33	7.23	2.71	24174.81	159.46
06	8.18	2.29	64.50	12.62	7.34	2.59	23303.18	158.20
07	7.19	3.71	57.70	11.46	7.32	2.71	24156.89	160.93
08	10.06	3.31	55.23	12.06	7.36	2.68	24354.18	158.59
09	9.69	2.94	52.54	10.12	6.86	2.72	25311.72	160.24
10	10.31	2.41	55.81	10.52	7.07	2.73	24826.89	159.10
11	7.35	3.89	53.89	8.10	6.89	2.89	25803.86	161.95
12	11.55	3.47	56.98	9.82	7.25	2.94	25341.19	161.33
13	10.15	3.36	57.78	10.82	7.45	2.97	24807.13	159.99
14	9.28	2.72	55.15	11.73	7.12	2.94	25235.38	159.59
15	6.45	2.33	55.05	8.85	7.36	2.88	24691.89	159.52
16	8.37	2.89	53.84	10.88	7.60	2.85	24955.74	160.11
17	7.15	1.36	55.07	11.78	7.59	2.88	24451.02	159.30
18	6.86	1.92	59.14	11.71	7.75	2.90	24342.61	159.57
19	8.73	2.62	63.08	11.29	7.52	2.89	24464.04	159.35
20	10.35	2.10	65.52	12.90	7.72	2.87	23931.24	159.26
21	10.78	2.99	66.32	11.09	8.09	2.97	23737.47	160.11
22	9.26	3.59	60.86	11.82	7.97	2.96	24004.96	159.27
23	7.97	3.84	61.39	12.06	7.57	2.94	24340.67	159.95
24	7.91	3.16	60.70	12.90	7.61	2.93	24098.09	159.71
25	7.76	3.65	60.39	11.13	7.42	3.04	24915.02	162.96
26	9.86	2.88	60.16	12.33	7.41	3.03	24594.62	160.83
27	7.55	3.23	60.46	9.96	7.26	3.13	24985.45	164.88
28	6.77	2.33	60.57	9.83	7.26	3.14	24668.58	163.82
29	7.88	3.14	63.88	10.48	7.90	3.17	24022.01	160.58
30	6.67	3.61	62.20	10.72	7.68	3.14	24329.67	161.46
31	6.32	3.20	61.74	9.99	7.66	3.14	24163.35	161.92
平均值	8.47	3.03	59.81	11.01	7.45	2.89	24481.59	160.68
最大值	11.55	4.50	66.32	12.90	8.09	3.17	25803.86	164.88
最小值	6.32	1.36	52.54	8.10	6.86	2.59	23303.18	158.20
排放標準	<60.00	<150.00	<220.00	<150.00		<10.00		
月排放量	251.19	68.85	2229.27	572.86	0.00	0.00	0.00	0.00