

嘉義市垃圾焚化廠CEMS煙囪監測系統月報

資料日期 2025/04

文件編號

煙囪編號:

P001

測項	氯化氫	一氧化碳	氮氧化物	二氧化硫	氧氣	不透光率	流速/流率	溫度
日/單位	ppm	ppm	ppm	ppm	%	%	m3/hr	℃
01	7.29	1.86	64.62	8.61	7.00	2.80	24880.28	162.05
02	8.28	2.06	66.06	9.07	7.24	2.80	24458.18	155.70
03	8.60	2.05	66.61	9.82	7.19	2.86	25089.73	158.81
04	7.49	1.99	64.70	9.10	7.13	2.89	25208.85	161.39
05	7.94	2.03	65.50	10.33	7.31	2.88	24698.71	159.79
06	8.45	1.72	64.70	10.75	7.40	2.90	24715.01	160.20
07	8.39	1.67	62.72	10.00	7.07	2.88	24876.58	156.65
08	8.36	1.67	63.24	9.87	6.98	2.89	24816.45	158.11
09	8.98	2.24	63.61	11.85	7.17	2.89	24560.98	157.00
10	7.89	2.09	62.22	9.39	6.89	2.86	25031.56	157.98
11	8.68	1.84	64.04	9.39	7.09	2.86	24864.39	159.21
12	9.20	2.06	65.32	9.71	7.23	2.89	24810.16	159.33
13	9.38	1.97	64.09	10.23	7.07	2.86	25020.46	158.45
14	7.46	2.01	63.38	10.29	6.98	2.57	24585.89	155.62
15	7.48	1.80	64.85	10.24	7.14	2.30	24661.38	158.95
16	8.98	1.97	65.26	11.80	7.13	2.33	24739.50	157.41
17	8.61	1.83	63.20	12.08	7.05	2.33	24986.45	157.46
18	7.74	1.85	65.83	9.84	7.47	2.37	24990.28	160.71
19	9.15	2.00	64.58	10.68	7.45	2.39	25180.38	159.80
20	9.09	1.72	64.30	11.12	7.37	2.44	25392.83	160.67
21	7.83	1.69	64.80	10.49	7.30	2.41	24429.20	158.94
22	7.65	1.76	62.22	10.24	6.88	2.43	25223.28	160.98
23	7.55	1.94	65.00	10.77	7.33	2.42	24531.17	157.37
24	7.35	2.19	65.43	11.50	7.58	2.42	24281.04	154.64
25	8.57	2.06	66.54	10.59	7.72	2.37	23773.29	155.45
26	2.67	31.80	37.11	11.39	23.24	2.21	23435.54	107.74
27	0.49	0.00	24.48	8.88	25.92	2.47	31982.01	46.41
28	0.69	0.38	32.61	7.38	24.28	2.54	18969.22	39.94
29	0.32	0.24	27.93	6.26	25.71	2.35	4739.32	36.27
30	0.20	0.01	22.77	7.01	25.89	2.34	307.18	34.74
31								
平均值	7.03	2.68	58.59	9.96	10.17	2.60	23307.98	140.93
最大值	9.38	31.80	66.61	12.08	25.92	2.90	31982.01	162.05
最小值	0.20	0.00	22.77	6.26	6.88	2.21	307.18	34.74
排放標準	<60.00	<150.00	<220.00	<150.00		<10.00		
月排放量	203.79	51.73	2076.08	488.67	0.00	0.00	0.00	0.00