

嘉義市垃圾焚化廠CEMS煙囪監測系統月報

資料日期 2025/04

文件編號

煙囪編號:

P002

測項	氯化氫	一氧化碳	氮氧化物	二氧化硫	氧氣	不透光率	流速/流率	溫度
日/單位	ppm	ppm	ppm	ppm	%	%	m3/hr	℃
01	7.07	3.39	61.24	10.09	7.65	3.16	24295.82	166.38
02	8.34	2.83	62.37	9.28	7.60	3.27	24175.16	163.88
03	8.44	2.74	63.03	10.14	7.60	3.33	24454.05	164.02
04	8.61	2.98	63.39	9.71	7.63	3.34	24515.35	164.68
05	9.42	3.43	61.10	9.85	7.59	3.35	24591.82	163.41
06	9.23	3.84	62.80	9.61	7.62	3.39	24609.63	163.90
07	7.58	3.28	63.87	8.83	7.90	3.43	24158.96	161.97
08	7.84	2.71	62.26	9.05	7.53	3.50	24450.07	162.10
09	8.04	2.89	62.70	10.77	7.56	3.58	24363.25	161.08
10	8.07	3.29	63.35	9.54	7.64	3.60	24307.91	164.00
11	6.92	3.55	62.01	7.62	7.61	3.61	24429.84	164.82
12	8.94	3.13	63.01	9.17	7.54	3.60	24435.53	164.60
13	8.51	3.33	60.39	9.06	7.69	3.56	24046.86	164.34
14	8.61	2.79	63.92	8.76	7.95	2.92	23788.75	161.96
15	7.80	2.48	62.61	9.82	7.58	2.15	24410.80	161.41
16	7.71	1.71	63.22	10.66	7.70	2.26	24052.58	160.22
17	8.68	2.69	64.24	11.51	7.77	2.34	24303.20	161.35
18	7.75	3.08	65.57	9.43	7.90	2.42	24521.21	167.43
19	7.75	3.94	64.63	10.70	7.83	2.36	24301.70	163.81
20	7.50	3.25	64.20	10.53	7.82	2.39	24277.22	164.69
21	7.86	2.37	64.24	10.15	7.90	2.39	23957.03	164.03
22	7.90	3.27	64.34	10.04	7.83	2.37	24176.24	165.62
23	7.01	2.99	63.95	10.82	7.64	2.33	24129.15	160.97
24	8.05	2.94	65.69	12.19	7.73	2.37	24144.50	161.01
25	9.13	2.92	65.24	10.29	7.47	2.38	24464.91	162.93
26	8.98	3.68	66.45	11.59	7.78	2.40	23832.30	163.10
27	7.67	3.06	64.03	10.28	7.88	2.44	23884.60	164.46
28	7.54	3.05	62.88	9.37	7.87	2.42	23766.88	163.97
29	8.25	2.92	61.56	9.79	7.57	2.44	24206.63	163.95
30	7.91	3.08	62.48	12.71	7.58	2.38	23777.73	163.27
31								
平均值	8.10	3.05	63.36	10.05	7.70	2.85	24227.66	163.45
最大值	9.42	3.94	66.45	12.71	7.95	3.61	24609.63	167.43
最小值	6.92	1.71	60.39	7.62	7.47	2.15	23766.88	160.22
排放標準	<60.00	<150.00	<220.00	<150.00		<10.00		
月排放量	230.55	66.65	2264.03	501.66	0.00	0.00	0.00	0.00