

嘉義市垃圾焚化廠CEMS煙囪監測系統月報

資料日期 2025/05

文件編號

煙囪編號:

P001

測項	氯化氫	一氧化碳	氮氧化物	二氧化硫	氧氣	不透光率	流速/流率	溫度
日/單位	ppm	ppm	ppm	ppm	%	%	m3/hr	℃
01	0.12	0.01	21.95	7.21	25.89	2.37	4892.21	34.54
02	0.58	0.05	23.26	7.81	25.70	2.40	20135.50	32.61
03	0.74	0.05	25.24	8.00	25.32	2.34	19354.18	33.44
04	0.54	0.03	28.61	7.14	25.26	2.36	13404.20	32.82
05	3.00	10.80	27.66	8.01	24.94	2.34	20568.51	35.14
06	7.47	37.33	32.28	10.53	24.35	2.33	14042.65	35.09
07	2.47	0.12	30.60	8.11	24.84	2.28	9384.44	40.80
08	1.18	10.28	30.24	14.51	24.50	2.29	13450.98	48.20
09	7.08	75.01	75.55	13.76	15.45	2.65	20719.40	130.68
10	4.50	10.29	62.05	10.13	8.10	2.81	22983.66	157.44
11	4.17	2.70	64.02	9.46	7.66	2.79	24087.92	160.84
12	5.41	2.56	61.41	11.94	7.90	2.76	23384.13	158.33
13	7.62	2.12	65.97	11.31	8.00	2.83	23177.81	162.71
14	6.88	2.12	67.92	12.06	7.76	2.83	23434.64	157.27
15	6.25	2.07	68.23	10.73	7.78	2.82	23246.94	159.32
16	6.41	2.02	66.73	9.97	7.85	2.82	23559.41	161.19
17	6.22	2.24	66.08	10.79	7.75	2.77	23376.75	159.40
18	5.75	2.20	62.72	10.48	7.51	2.78	23859.20	160.69
19	6.38	1.98	65.30	13.32	7.91	2.76	23552.27	158.11
20	8.28	1.93	66.85	14.59	7.62	2.77	23624.14	158.52
21	7.05	2.10	67.38	13.77	7.70	2.80	23516.49	158.02
22	6.13	2.05	66.92	11.71	8.05	2.85	23272.66	160.10
23	7.13	2.22	66.29	12.21	8.01	2.85	23144.15	159.01
24	7.85	2.32	65.12	13.73	8.05	2.80	23184.40	155.64
25	8.16	1.87	65.63	13.41	7.87	2.78	23405.02	156.97
26	9.37	1.86	67.65	14.30	8.15	2.77	22972.92	155.75
27	7.67	1.74	67.46	12.13	7.99	2.76	23478.87	156.31
28	7.81	2.18	68.08	10.38	7.97	2.70	23368.49	158.14
29	7.87	2.45	66.88	9.44	8.29	2.72	22806.60	159.88
30	7.16	2.07	67.09	3.40	7.74	2.73	23639.83	161.06
31	8.23	1.92	66.33	5.19	7.53	2.78	23957.66	160.02
平均值	5.66	6.09	56.37	10.63	12.56	2.67	20999.55	126.39
最大值	9.37	75.01	75.55	14.59	25.89	2.85	24087.92	162.71
最小值	0.12	0.01	21.95	3.40	7.51	2.28	4892.21	32.61
排放標準	<60.00	<150.00	<220.00	<150.00		<10.00		
月排放量	154.87	115.32	1906.73	484.59	0.00	0.00	0.00	0.00