

嘉義市垃圾焚化廠CEMS煙囪監測系統月報

資料日期 2025/05

文件編號

煙囪編號:

P002

測項	氯化氫	一氧化碳	氮氧化物	二氧化硫	氧氣	不透光率	流速/流率	溫度
日/單位	ppm	ppm	ppm	ppm	%	%	m3/hr	°C
01	3.40	32.65	29.64	6.41	21.93	2.40	23171.83	110.68
02	2.55	0.43	18.05	2.12	24.65	2.36	31799.01	54.16
03	2.05	0.25	18.43	0.61	24.74	2.34	61691.01	45.66
04	0.99	0.19	22.97	0.36	24.70	2.36	12443.33	40.97
05	3.69	8.63	23.29	1.22	24.20	2.37	9177.62	40.11
06	5.08	28.35	22.02	1.88	23.70	2.55	3510.47	36.10
07	1.98	0.34	20.66	0.01	24.40	2.68	4362.58	36.27
08	1.50	3.59	21.68	1.77	24.23	2.69	4437.95	38.03
09	0.69	4.74	36.61	0.57	23.27	2.80	4296.14	44.03
10	3.29	25.78	46.99	3.36	22.29	2.75	11246.98	48.20
11	2.09	42.86	59.45	6.87	15.61	2.77	17540.01	131.00
12	1.96	15.36	66.22	8.46	7.41	2.88	25091.30	161.97
13	5.79	6.45	61.13	5.87	6.88	2.86	25548.38	166.56
14	5.78	3.71	62.20	5.29	6.78	2.92	25776.87	164.15
15	4.50	3.99	63.40	4.65	6.93	2.92	25230.64	163.86
16	3.97	2.11	62.82	4.19	6.65	3.00	26549.82	165.94
17	4.05	3.15	64.27	4.72	6.83	2.95	26375.74	164.41
18	4.36	2.75	62.78	5.22	7.24	2.99	26315.67	164.09
19	6.04	1.51	63.02	5.19	7.24	2.99	25906.40	162.98
20	7.62	1.40	63.50	4.44	7.04	2.97	25984.18	162.63
21	4.49	1.12	64.13	3.57	7.32	2.97	25875.20	163.35
22	6.65	1.15	63.62	3.93	7.11	2.98	26089.70	162.93
23	6.90	1.72	63.64	4.28	7.11	2.99	25981.00	162.58
24	8.00	2.12	65.59	5.23	7.03	2.99	25820.91	162.59
25	3.92	1.47	65.46	4.42	6.82	3.00	26204.55	162.71
26	4.96	0.85	66.36	4.31	7.15	3.00	25511.81	162.60
27	4.67	1.13	65.50	3.55	7.06	3.03	25702.60	162.46
28	3.59	1.19	68.07	3.51	7.16	3.08	25482.05	162.77
29	4.63	1.13	67.82	4.90	7.58	3.09	24851.10	162.75
30	3.54	2.39	66.79	6.72	7.63	3.17	24961.21	163.44
31	4.28	2.10	66.67	7.89	7.62	3.22	24941.06	163.29
平均值	4.10	6.60	52.03	4.05	12.78	2.84	22512.17	125.59
最大值	8.00	42.86	68.07	8.46	24.74	3.22	61691.01	166.56
最小值	0.69	0.19	18.05	0.01	6.65	2.34	3510.47	36.10
排放標準	<60.00	<150.00	<220.00	<150.00		<10.00		
月排放量	116.57	95.00	1865.58	206.71	0.00	0.00	0.00	0.00