

嘉義市垃圾焚化廠CEMS煙囪監測系統月報

資料日期 2025/06

文件編號

煙囪編號:

P001

測項	氯化氫	一氧化碳	氮氧化物	二氧化硫	氧氣	不透光率	流速/流率	溫度
日/單位	ppm	ppm	ppm	ppm	%	%	m3/hr	°C
01	7.70	1.91	66.34	3.86	7.66	2.79	23990.21	161.92
02	7.95	2.21	65.92	5.32	7.78	2.77	23673.97	159.79
03	4.78	1.81	65.15	8.20	7.78	2.80	24393.20	162.06
04	6.62	1.70	65.05	9.87	7.97	2.79	24058.29	161.80
05	8.40	1.88	65.48	4.98	7.93	2.82	24204.95	164.03
06	7.54	2.25	66.37	4.48	7.86	2.79	24176.85	163.64
07	11.01	2.67	67.91	5.90	8.07	2.79	24109.25	162.85
08	10.44	2.29	67.15	4.69	7.72	2.74	24339.98	160.98
09	11.21	2.86	68.47	5.41	7.78	2.68	24050.23	160.49
10	11.46	2.12	66.65	4.58	7.55	2.67	23921.68	159.70
11	10.59	3.19	67.62	7.62	7.73	2.63	23683.95	153.87
12	8.90	2.23	67.64	2.81	7.73	2.62	23995.43	153.59
13	9.31	2.01	66.75	2.77	7.70	2.64	24196.66	154.45
14	9.13	2.13	67.00	2.49	8.00	2.64	23739.91	155.71
15	8.35	2.04	68.51	2.45	7.83	2.62	23745.94	155.81
16	8.63	1.94	68.75	2.90	7.99	2.53	23957.20	156.78
17	7.58	1.60	67.44	2.99	8.03	2.43	23531.58	157.40
18	8.00	1.89	66.20	3.11	7.59	2.42	24052.01	158.00
19	8.85	1.54	67.25	2.67	7.55	2.38	24155.24	155.23
20	9.99	1.57	68.31	6.19	7.60	2.38	24476.76	160.15
21	10.29	1.74	66.26	6.66	7.58	2.30	23814.80	154.34
22	10.33	1.76	67.04	7.92	7.43	2.28	24225.47	155.16
23	10.02	2.36	65.09	9.55	7.51	2.24	24247.96	153.08
24	5.10	1.67	65.86	5.13	7.53	2.22	24119.32	155.72
25	9.71	2.21	68.40	6.43	8.04	2.17	23466.78	153.08
26	8.48	1.63	65.62	5.83	7.84	2.18	23727.48	154.42
27	7.61	1.70	65.46	5.20	7.64	2.20	24245.69	157.24
28	8.83	1.71	65.24	6.91	7.57	2.19	23957.10	155.34
29	8.58	1.85	64.25	8.14	7.42	2.17	24003.02	154.59
30	9.19	1.59	65.11	7.06	7.43	2.18	24324.15	157.25
31								
平均值	8.82	2.00	66.61	5.40	7.73	2.50	24019.50	157.62
最大值	11.46	3.19	68.75	9.87	8.07	2.82	24476.76	164.03
最小值	4.78	1.54	64.25	2.45	7.42	2.17	23466.78	153.08
排放標準	<60.00	<150.00	<220.00	<150.00		<10.00		
月排放量	248.81	43.08	2360.16	268.06	0.00	0.00	0.00	0.00