

嘉義市垃圾焚化廠CEMS煙囪監測系統月報

資料日期 2025/06

文件編號

煙囪編號:

P002

測項	氯化氫	一氧化碳	氮氧化物	二氧化硫	氧氣	不透光率	流速/流率	溫度
日/單位	ppm	ppm	ppm	ppm	%	%	m3/hr	℃
01	3.47	1.74	67.59	5.93	7.38	3.21	25412.07	163.51
02	3.53	2.53	67.05	3.48	7.60	3.28	24640.29	162.81
03	0.59	2.18	65.84	4.38	7.41	3.31	25427.45	163.38
04	2.15	2.37	66.04	6.19	7.81	3.34	24735.93	163.78
05	2.40	2.51	67.51	4.36	8.07	3.36	24403.16	163.79
06	4.34	2.47	66.60	3.99	7.96	3.37	24698.50	163.17
07	5.93	2.64	61.87	5.20	7.37	3.41	26209.32	164.41
08	6.42	3.76	62.41	5.84	7.30	3.45	26104.64	163.81
09	5.53	4.35	62.49	7.41	7.54	3.46	25434.07	164.41
10	7.19	3.59	63.36	8.05	7.54	3.48	24865.55	163.25
11	6.13	7.24	64.99	8.55	7.95	3.48	24549.05	159.15
12	5.02	7.99	64.29	4.35	7.68	3.49	25105.40	155.64
13	4.26	4.08	63.91	2.32	7.30	3.45	26804.84	156.33
14	4.49	4.32	63.66	2.89	7.34	3.49	26559.94	157.68
15	5.72	4.09	63.14	2.38	7.16	3.54	26416.34	157.13
16	4.45	3.05	64.64	3.30	7.09	2.80	26697.95	158.42
17	0.69	1.97	63.82	3.42	6.97	1.76	26974.24	159.15
18	4.90	2.46	63.12	4.75	7.04	1.77	26538.38	160.56
19	5.84	3.07	64.51	3.09	7.18	1.79	26409.60	157.96
20	7.23	3.25	64.16	6.49	7.01	1.82	27093.88	158.31
21	7.31	3.00	64.32	7.01	7.01	1.82	26449.23	156.66
22	9.54	2.15	65.59	9.60	6.96	1.85	26681.09	157.35
23	5.35	3.35	65.68	7.77	7.63	1.86	26241.50	157.21
24	4.43	2.23	61.93	5.81	7.07	1.89	26475.06	158.03
25	6.18	2.86	62.78	8.19	7.04	1.88	26721.45	157.76
26	4.76	3.02	64.75	4.10	7.41	1.90	26113.66	156.98
27	6.79	2.24	63.94	5.51	7.22	1.93	26762.51	160.19
28	4.76	1.72	63.00	5.68	7.16	1.93	26271.75	157.54
29	5.97	1.77	61.04	7.63	7.04	1.95	26594.33	158.45
30	6.08	1.97	61.07	6.52	6.90	1.98	26621.90	158.38
31								
平均值	5.05	3.13	64.17	5.47	7.34	2.67	26000.44	159.84
最大值	9.54	7.99	67.59	9.60	8.07	3.54	27093.88	164.41
最小值	0.59	1.72	61.04	2.32	6.90	1.76	24403.16	155.64
排放標準	<60.00	<150.00	<220.00	<150.00		<10.00		
月排放量	154.48	72.82	2456.92	293.41	0.00	0.00	0.00	0.00