

# 嘉義市垃圾焚化廠CEMS煙囪監測系統月報

資料日期 2025/07

文件編號

煙囪編號:

P001

測項	氯化氫	一氧化碳	氮氧化物	二氧化硫	氧氣	不透光率	流速/流率	溫度
日/單位	ppm	ppm	ppm	ppm	%	%	m3/hr	°C
01	8.38	2.62	65.75	5.53	7.40	2.16	23996.39	156.88
02	8.17	3.11	68.59	7.90	8.04	2.12	23315.37	154.32
03	7.49	2.28	64.93	9.55	7.83	2.10	23679.03	153.30
04	8.16	1.72	67.22	6.87	7.67	2.09	23790.34	156.41
05	8.33	1.86	66.85	6.46	7.53	2.07	24132.15	154.10
06	5.62	9.15	73.04	4.55	8.12	2.10	23757.95	158.66
07	9.01	2.45	66.44	8.11	7.74	2.03	24183.36	152.92
08	8.30	2.56	66.93	8.08	7.93	2.03	23428.23	153.46
09	11.85	3.50	65.25	9.18	7.77	2.01	23871.57	150.47
10	7.86	3.55	66.18	8.89	7.82	1.99	24100.42	149.92
11	10.54	2.45	65.19	7.44	7.53	2.41	24300.18	150.57
12	11.56	2.46	65.88	8.09	7.52	2.68	24078.15	151.65
13	11.13	2.53	65.11	9.96	7.36	2.67	24214.20	154.02
14	12.05	2.51	65.61	8.54	7.16	2.67	24728.53	152.66
15	10.32	2.35	67.45	7.42	7.68	2.70	24057.44	153.45
16	11.77	2.61	67.04	9.45	7.60	2.69	23948.58	150.92
17	10.86	2.78	65.00	7.59	7.36	2.70	24125.07	152.72
18	9.65	2.29	65.61	6.76	7.16	2.71	24474.86	151.91
19	9.45	2.24	65.38	5.73	7.18	2.67	24789.74	153.00
20	11.51	2.48	66.01	7.41	7.42	2.67	24400.43	154.18
21	9.40	2.38	66.22	6.74	7.09	2.69	24725.12	154.30
22	9.03	2.63	67.63	3.59	7.26	2.69	24210.96	154.51
23	9.09	2.51	68.16	5.10	7.54	2.67	23869.39	151.67
24	9.07	2.59	67.69	5.86	7.50	2.66	24047.10	153.60
25	9.84	2.55	67.46	4.78	7.46	2.67	23934.27	152.68
26	8.54	2.47	67.45	4.79	7.59	2.68	23862.02	153.90
27	9.16	2.31	66.74	5.29	7.56	2.67	24059.39	154.04
28	10.06	2.14	66.15	4.77	7.33	2.66	24249.36	154.54
29	7.37	1.87	67.20	2.34	7.61	2.57	24386.64	155.19
30	8.17	2.24	66.99	4.92	8.00	2.53	24014.75	153.68
31	9.89	1.95	67.50	6.85	7.98	2.49	24150.63	147.41
平均值	9.41	2.68	66.73	6.73	7.57	2.46	24092.96	153.26
最大值	12.05	9.15	73.04	9.96	8.12	2.71	24789.74	158.66
最小值	5.62	1.72	64.93	2.34	7.09	1.99	23315.37	147.41
排放標準	<60.00	<150.00	<220.00	<150.00		<10.00		
月排放量	275.71	57.79	2448.78	345.47	0.00	0.00	0.00	0.00