

# 嘉義市垃圾焚化廠CEMS煙囪監測系統月報

資料日期 2025/07

文件編號

煙囪編號:

P002

測項	氯化氫	一氧化碳	氮氧化物	二氧化硫	氧氣	不透光率	流速/流率	溫度
日/單位	ppm	ppm	ppm	ppm	%	%	m3/hr	°C
01	5.09	2.04	65.03	5.87	7.33	2.00	25592.62	159.18
02	5.52	2.94	65.37	8.59	7.41	2.01	25577.69	158.76
03	5.64	3.43	61.54	6.62	7.37	2.04	25385.68	156.57
04	6.56	2.98	62.77	6.68	7.16	2.04	25964.83	160.84
05	6.00	2.94	66.79	6.34	7.55	2.05	25511.93	158.58
06	5.99	2.88	64.20	5.39	7.35	2.05	25622.57	160.63
07	10.34	2.35	65.22	6.13	7.48	2.05	25192.84	155.83
08	11.54	3.50	64.03	8.37	7.49	2.13	25549.90	158.02
09	12.03	3.56	61.96	9.82	7.08	2.15	25919.73	154.80
10	12.00	2.24	65.18	8.77	7.21	2.34	25943.69	155.73
11	10.06	2.30	65.29	7.87	7.48	2.57	26000.85	156.10
12	10.81	3.28	66.32	9.71	7.64	2.66	25453.59	156.01
13	7.77	2.76	64.58	10.26	7.36	2.71	25663.74	155.99
14	7.76	3.44	62.90	10.57	6.99	2.76	26232.58	156.82
15	4.65	2.87	64.21	9.10	7.23	2.83	25745.51	160.52
16	6.84	2.89	62.18	10.44	7.22	2.85	25864.54	157.95
17	7.21	3.09	63.53	9.25	7.39	2.87	25449.17	158.05
18	4.41	2.75	62.84	8.20	7.18	2.88	25837.70	159.14
19	8.48	4.88	61.86	10.10	7.32	2.89	26153.81	159.44
20	9.81	4.30	62.20	9.76	7.19	2.89	26207.97	158.35
21	9.63	3.65	62.43	10.62	7.45	2.89	25159.19	158.90
22	5.98	2.82	61.40	8.76	7.98	2.90	24644.03	159.03
23	19.38	5.59	62.48	12.57	8.33	2.91	23821.59	157.13
24	11.10	5.42	63.95	8.69	8.44	2.93	23580.85	154.63
25	4.83	3.40	65.76	6.57	8.08	2.97	24496.48	157.62
26	5.04	3.33	64.31	4.98	7.82	2.99	24758.74	158.91
27	8.02	3.48	63.82	6.75	7.70	3.01	25054.53	161.13
28	6.30	2.98	64.51	6.12	7.51	3.02	25203.36	159.99
29	3.45	3.58	62.72	4.49	7.46	3.03	25152.59	163.75
30	3.43	3.68	64.67	5.95	7.75	3.09	25022.48	162.96
31	4.10	2.99	65.52	8.13	7.93	3.14	25118.79	161.14
平均值	7.73	3.30	63.86	8.11	7.51	2.63	25383.34	158.47
最大值	19.38	5.59	66.79	12.57	8.44	3.14	26232.58	163.75
最小值	3.43	2.04	61.40	4.49	6.99	2.00	23580.85	154.63
排放標準	<60.00	<150.00	<220.00	<150.00		<10.00		
月排放量	237.86	77.68	2471.40	439.21	0.00	0.00	0.00	0.00