

嘉義市垃圾焚化廠CEMS煙囪監測系統月報

資料日期 114年8月

文件編號

煙囪編號:

P001

測項	氯化氫	一氧化碳	氮氧化物	二氧化硫	氧氣	不透光率	流速/流率	溫度
日/單位	ppm	ppm	ppm	ppm	%	%	m3/hr	°C
01	9.25	1.61	65.02	5.54	8.13	2.49	24166.11	147.17
02	11.13	2.20	66.40	6.53	7.95	2.49	24106.35	145.05
03	9.36	2.05	65.65	6.35	7.97	2.49	24292.13	148.62
04	9.23	2.35	65.11	6.74	8.07	2.49	24478.56	146.90
05	8.84	1.66	62.95	6.18	8.07	2.50	24049.87	148.33
06	9.66	1.73	62.88	7.62	7.47	2.50	24509.70	147.66
07	8.79	2.10	60.10	6.02	6.78	2.53	24888.28	152.78
08	8.74	2.15	61.46	6.69	7.04	2.51	24539.11	152.71
09	12.29	3.83	64.33	7.79	8.22	2.42	22990.20	149.23
10	9.64	1.83	63.42	7.77	7.67	2.47	24031.23	152.14
11	9.33	2.02	62.20	7.37	7.56	2.47	23940.23	152.80
12	8.60	2.06	63.20	6.08	7.69	2.46	23981.00	154.52
13	8.93	1.92	64.81	5.74	7.38	2.46	24291.58	153.68
14	10.16	2.09	66.19	6.16	7.51	2.46	23869.67	151.78
15	10.38	2.53	63.93	5.83	6.99	2.46	24563.03	151.44
16	10.18	3.48	61.84	5.96	6.81	2.46	24703.29	150.63
17	10.01	2.94	62.90	6.13	7.09	2.46	24433.89	150.84
18	10.36	2.35	63.20	6.94	7.25	2.47	24027.18	151.95
19	9.12	2.74	63.23	6.02	7.07	2.46	24196.87	152.66
20	9.97	2.78	63.10	6.72	7.13	2.45	24326.35	152.03
21	14.15	4.27	64.91	6.87	7.39	2.42	23771.96	148.53
22	9.83	4.78	63.56	6.46	7.19	2.43	24050.03	150.40
23	9.37	4.44	64.37	6.23	7.13	2.43	24339.27	149.56
24	8.57	2.75	62.89	6.35	6.87	2.42	25195.75	153.00
25	3.87	36.99	41.49	17.09	22.28	2.14	23643.63	103.89
26	1.05	2.94	28.91	10.71	25.17	2.02	29393.74	51.22
27	6.51	40.66	57.21	12.25	12.87	2.29	22553.16	128.15
28	9.07	2.16	62.91	8.38	7.37	2.42	24177.54	151.66
29	9.30	2.18	64.24	7.77	7.50	2.42	23795.39	151.21
30	9.13	2.37	63.34	8.55	7.49	2.42	23885.90	150.21
31	9.55	2.14	62.57	8.19	7.24	2.37	24295.05	152.61
平均值	9.17	4.91	61.56	7.39	8.66	2.43	24306.00	145.27
最大值	14.15	40.66	66.40	17.09	25.17	2.53	29393.74	154.52
最小值	1.05	1.61	28.91	5.54	6.78	2.02	22553.16	51.22
排放標準	<60.00	<150.00	<85.00	<150.00		<10.00		
月排放量	269.77	102.52	2274.76	380.54				