

嘉義市垃圾焚化廠CEMS煙囪監測系統月報

資料日期 114年8月

文件編號

煙囪編號:

P002

測項	氯化氫	一氧化碳	氮氧化物	二氧化硫	氧氣	不透光率	流速/流率	溫度
日/單位	ppm	ppm	ppm	ppm	%	%	m3/hr	°C
01	5.65	2.93	64.96	8.23	7.70	3.17	25324.99	161.30
02	7.41	2.08	66.37	8.43	7.50	3.17	25258.73	157.94
03	7.59	2.35	66.16	7.64	7.41	3.18	25332.64	160.67
04	5.85	3.67	65.32	7.85	7.78	3.23	25221.51	162.23
05	4.19	2.93	66.71	8.02	8.06	3.28	24630.24	164.06
06	7.83	2.61	66.81	10.77	7.96	3.40	24057.39	163.79
07	7.38	3.64	66.14	7.40	7.80	3.45	24182.78	163.90
08	6.97	3.24	65.35	10.09	7.71	3.47	24045.66	163.40
09	10.68	3.36	67.17	9.17	8.20	3.49	23231.07	161.67
10	7.81	2.11	66.01	8.31	7.70	3.56	24193.28	163.60
11	8.03	3.19	63.83	8.28	7.54	3.62	24192.48	163.57
12	8.42	3.23	63.58	7.71	7.52	3.72	24473.24	163.64
13	6.65	2.25	61.97	8.49	7.15	3.73	24940.93	163.70
14	9.76	2.24	65.84	10.41	7.88	3.25	23807.79	162.72
15	8.26	1.85	65.11	8.75	7.91	2.64	23885.97	163.25
16	9.46	2.54	66.16	9.60	8.08	2.66	23217.88	163.01
17	8.78	1.41	64.46	9.83	7.92	2.69	23552.11	162.87
18	7.54	1.94	64.85	9.63	7.98	2.73	23475.90	163.54
19	6.68	1.88	65.87	8.28	7.99	2.76	23612.39	163.69
20	8.50	3.14	65.44	9.44	7.95	2.76	23547.88	164.06
21	7.65	4.36	65.27	9.17	8.34	2.85	22418.75	162.60
22	7.17	4.26	67.11	9.09	8.49	2.93	22433.13	163.14
23	8.51	4.08	67.93	8.69	8.40	2.98	22734.68	163.24
24	8.95	3.25	66.91	8.83	8.29	3.01	22956.64	163.66
25	9.34	3.53	64.78	11.28	8.31	3.05	23206.63	164.35
26	5.24	1.09	66.44	7.86	8.48	3.06	23030.42	163.10
27	5.15	1.66	65.52	9.56	8.19	3.10	22813.86	163.15
28	5.70	2.40	66.00	10.72	8.47	3.19	22644.75	162.45
29	6.99	2.27	65.92	10.79	8.63	3.20	22407.98	161.99
30	6.73	3.16	64.82	12.13	8.11	3.19	22456.81	162.16
31	4.03	2.71	64.71	11.81	8.33	3.30	22873.34	163.22
平均值	7.38	2.75	65.60	9.23	7.99	3.16	23682.64	162.89
最大值	10.68	4.36	67.93	12.13	8.63	3.73	25332.64	164.35
最小值	4.03	1.09	61.97	7.40	7.15	2.64	22407.98	157.94
排放標準	<60.00	<150.00	<85.00	<150.00		<10.00		
月排放量	212.45	60.30	2372.33	464.03				