

嘉義市垃圾焚化廠CEMS煙囪監測系統月報

資料日期 114年9月

文件編號

煙囪編號:

P001

測項	氯化氫	一氧化碳	氮氧化物	二氧化硫	氧氣	不透光率	流速/流率	溫度
日/單位	ppm	ppm	ppm	ppm	%	%	m3/hr	°C
01	11.63	1.81	63.18	8.06	7.31	2.36	24195.54	151.19
02	8.82	1.84	65.13	7.69	7.46	2.36	24010.04	152.93
03	9.70	1.87	64.76	8.39	7.33	2.37	24176.14	152.37
04	9.58	1.88	65.20	8.04	7.38	2.37	24105.67	151.82
05	9.33	2.37	65.62	7.28	7.34	2.38	24040.37	153.09
06	8.16	2.81	63.76	8.65	7.30	2.35	24059.32	150.61
07	7.96	2.03	62.95	8.59	7.35	2.35	23882.88	152.13
08	9.27	3.11	62.27	7.62	7.08	2.36	24382.83	151.23
09	8.27	2.26	64.80	6.99	7.15	2.37	24237.95	154.81
10	9.04	2.03	64.30	7.73	6.87	2.37	24691.23	152.54
11	10.67	2.21	63.93	8.08	7.10	2.37	24363.01	150.95
12	8.06	2.25	65.96	7.04	7.40	2.39	23943.57	155.00
13	8.60	2.52	64.93	7.30	7.21	2.38	24249.05	153.92
14	8.88	2.46	64.19	8.20	7.36	2.38	24041.93	153.93
15	8.07	2.29	63.83	6.86	7.06	2.38	24503.59	151.93
16	6.67	2.78	63.35	7.00	6.85	2.39	24946.11	154.68
17	8.48	2.76	64.58	7.23	7.07	2.37	24481.03	152.33
18	8.38	2.23	64.59	6.39	7.08	2.39	24229.08	156.55
19	7.45	2.04	65.61	5.44	7.42	2.39	24226.65	157.74
20	8.23	2.06	64.72	6.56	7.14	2.39	24200.13	155.91
21	7.13	1.68	63.70	6.65	7.02	2.40	24333.03	157.42
22	8.61	3.13	66.13	6.03	7.41	2.39	24255.55	157.17
23	8.80	1.56	66.10	6.62	7.25	2.40	24540.57	157.45
24	8.55	1.46	63.80	9.00	7.16	2.41	24305.94	156.74
25	8.79	2.18	64.19	8.15	7.28	2.40	24024.66	155.32
26	7.21	1.64	64.88	6.84	7.28	2.40	24162.43	158.27
27	8.06	1.86	64.61	6.96	7.36	2.39	23826.41	155.18
28	9.74	1.70	65.68	8.54	7.47	2.39	23931.66	155.84
29	9.06	1.54	64.93	8.06	7.55	2.40	24089.17	157.56
30	9.06	1.50	65.16	8.10	7.45	2.39	23951.86	158.17
31								
平均值	8.68	2.13	64.56	7.47	7.25	2.38	24212.91	154.49
最大值	11.63	3.13	66.13	9.00	7.55	2.41	24946.11	158.27
最小值	6.67	1.46	62.27	5.44	6.85	2.35	23826.41	150.61
排放標準	<60.00	<150.00	<85.00	<150.00		<10.00		
月排放量	247.07	46.54	2306.47	372.79				