

嘉義市垃圾焚化廠CEMS煙囪監測系統月報

資料日期 114年9月

文件編號

煙囪編號:

P002

測項	氯化氫	一氧化碳	氮氧化物	二氧化硫	氧氣	不透光率	流速/流率	溫度
日/單位	ppm	ppm	ppm	ppm	%	%	m3/hr	°C
01	5.74	2.51	65.36	10.94	8.61	3.32	22431.96	163.30
02	8.16	3.16	67.32	9.18	8.42	3.34	22761.97	163.36
03	6.27	3.32	66.94	8.54	8.26	3.37	23249.53	160.32
04	6.82	3.82	67.02	9.69	8.39	3.42	23103.88	159.00
05	5.94	3.62	66.67	9.07	8.71	3.46	22576.06	161.47
06	6.12	3.88	66.80	11.14	8.46	3.49	22337.01	163.28
07	3.70	3.21	66.80	10.31	8.36	3.51	22157.37	162.83
08	7.02	3.06	66.16	10.65	8.27	3.59	22512.57	162.68
09	6.97	3.03	66.44	10.72	8.53	3.67	22449.20	163.37
10	4.55	3.57	66.83	11.55	8.56	3.69	22494.11	163.24
11	2.04	3.17	66.20	10.69	8.26	3.70	22539.02	162.47
12	3.29	2.41	66.13	9.66	8.16	3.35	22740.49	162.93
13	4.84	2.80	65.64	10.08	8.50	2.61	22091.95	161.88
14	4.59	2.84	62.87	10.42	8.11	2.62	22319.18	162.51
15	5.12	3.06	66.80	10.12	8.44	2.70	22154.47	163.01
16	5.31	2.21	64.68	8.31	8.52	2.81	22305.72	164.29
17	9.85	2.04	65.50	9.56	8.72	2.88	21946.78	163.27
18	8.12	1.89	64.96	9.51	8.44	2.91	22430.55	163.65
19	8.01	2.10	63.51	9.73	8.37	2.96	21643.66	162.47
20	7.80	2.04	65.60	9.40	8.54	3.02	22165.44	163.12
21	6.80	2.08	65.08	9.47	8.37	3.06	22132.18	163.23
22	8.48	2.49	65.31	9.67	8.43	3.15	22272.81	162.55
23	7.75	1.91	64.93	8.34	8.73	3.18	21982.77	163.26
24	4.64	1.59	63.79	9.63	8.70	3.22	21681.28	163.22
25	6.92	1.64	65.54	9.34	8.47	2.89	21890.01	162.74
26	4.80	2.31	65.08	7.75	8.07	2.49	22881.02	163.22
27	9.43	2.83	64.93	8.05	7.93	2.54	22645.21	161.70
28	11.58	2.35	65.73	7.49	8.28	2.62	22575.22	162.35
29	10.82	2.37	63.57	7.74	8.16	2.68	22887.08	162.61
30	9.44	1.83	62.78	7.92	7.65	2.75	23437.93	162.15
31								
平均值	6.70	2.64	65.50	9.49	8.38	3.10	22426.55	162.65
最大值	11.58	3.88	67.32	11.55	8.73	3.70	23437.93	164.29
最小值	2.04	1.59	62.78	7.49	7.65	2.49	21643.66	159.00
排放標準	<60.00	<150.00	<85.00	<150.00		<10.00		
月排放量	177.05	53.05	2169.13	437.59				