

嘉義市垃圾焚化廠CEMS煙囪監測系統月報

資料日期 114年10月

文件編號

煙囪編號:

P001

測項	氯化氫	一氧化碳	氮氧化物	二氧化硫	氧氣	不透光率	流速/流率	溫度
日/單位	ppm	ppm	ppm	ppm	%	%	m3/hr	°C
01	10.54	2.08	64.22	8.54	7.19	2.39	23987.21	156.65
02	9.86	2.07	63.25	8.65	7.10	2.39	24046.02	156.79
03	8.94	2.85	64.38	8.13	7.63	2.38	23758.84	156.23
04	9.62	2.12	63.94	8.57	7.65	2.37	23530.47	154.21
05	8.65	2.40	63.53	8.62	7.48	2.38	23786.52	157.40
06	9.41	2.07	63.69	8.04	7.35	2.39	23977.41	156.41
07	8.62	1.53	64.27	7.49	7.53	2.38	23902.68	161.36
08	8.93	2.23	63.84	7.46	7.45	2.37	23705.34	155.12
09	9.95	1.87	64.03	8.25	7.41	2.38	23759.97	157.56
10	10.27	2.00	63.60	9.02	7.40	2.36	23751.82	153.91
11	8.08	1.78	64.08	9.51	7.53	2.36	23590.93	154.49
12	8.55	1.72	64.11	7.70	7.46	2.37	23555.88	156.77
13	8.26	2.15	64.52	8.42	7.53	2.35	23553.63	154.71
14	10.41	1.97	63.73	10.44	7.50	2.34	23619.42	153.76
15	9.77	2.74	62.43	12.35	7.23	2.34	24072.72	151.29
16	6.75	2.71	61.57	14.55	7.15	2.35	24221.46	151.49
17	9.76	2.53	65.04	12.93	7.05	2.44	24539.75	154.19
18	8.38	2.57	64.35	10.77	7.23	2.57	24124.00	151.15
19	10.86	1.59	65.00	10.04	7.36	2.61	23996.76	155.62
20	10.83	1.57	63.93	11.39	7.45	2.62	24029.58	154.47
21	10.65	1.74	65.20	8.88	7.62	2.64	23869.79	155.81
22	12.28	2.04	66.81	9.38	7.71	2.64	23437.00	154.93
23	16.14	1.91	66.65	10.18	7.71	2.63	23398.02	153.19
24	11.65	1.88	66.89	8.03	7.73	2.63	23494.82	156.82
25	12.18	1.76	65.88	8.07	7.62	2.63	23553.57	153.58
26	12.91	1.94	65.84	9.27	7.43	2.66	23860.15	155.97
27	12.57	2.29	65.67	9.69	7.40	2.66	23796.32	153.81
28	10.03	1.73	65.34	8.39	7.39	2.67	23902.65	156.39
29	10.20	1.79	65.91	9.15	7.34	2.68	23911.54	154.96
30	10.80	1.77	65.74	8.68	7.30	2.58	24334.28	154.65
31	11.19	1.75	64.71	8.30	7.32	2.46	24108.42	157.22
平均值	10.23	2.04	64.59	9.32	7.43	2.48	23844.42	155.19
最大值	16.14	2.85	66.89	14.55	7.73	2.68	24539.75	161.36
最小值	6.75	1.53	61.57	7.46	7.05	2.34	23398.02	151.15
排放標準	<60.00	<150.00	<85.00	<150.00		<10.00		
月排放量	295.00	45.33	2345.79	472.43				