

嘉義市垃圾焚化廠CEMS煙囪監測系統月報

資料日期 114年10月

文件編號

煙囪編號:

P002

測項	氯化氫	一氧化碳	氮氧化物	二氧化硫	氧氣	不透光率	流速/流率	溫度
日/單位	ppm	ppm	ppm	ppm	%	%	m3/hr	°C
01	11.73	2.12	65.81	8.02	8.01	2.84	22761.25	161.95
02	12.54	2.44	65.25	7.98	8.00	2.88	22709.66	161.44
03	9.46	3.69	65.95	7.10	8.30	2.97	23055.16	162.58
04	9.68	5.40	65.11	9.36	8.32	3.01	22937.07	162.52
05	11.33	2.66	65.24	7.64	8.25	3.05	23121.90	163.05
06	11.11	2.14	63.90	7.65	8.20	3.09	23309.65	162.68
07	7.63	1.56	62.71	7.56	8.14	3.15	23026.33	164.56
08	8.10	2.42	65.61	7.94	8.22	3.23	23282.41	164.33
09	8.13	2.56	65.02	8.48	7.90	3.28	23667.41	163.75
10	10.47	2.56	65.12	8.71	8.00	3.34	23487.04	163.55
11	12.48	2.18	65.61	7.35	8.18	3.39	23278.54	161.39
12	9.99	1.93	64.45	6.61	7.85	3.42	23485.49	160.56
13	9.30	3.57	64.50	16.76	8.01	3.47	22962.99	159.37
14	10.56	2.99	65.72	11.17	8.05	3.54	23509.96	161.39
15	6.70	5.18	64.79	14.26	8.32	3.61	22965.85	159.54
16	1.05	4.36	62.51	15.98	8.08	3.66	23090.98	157.84
17	1.90	3.05	61.94	11.66	7.67	3.23	23692.30	162.69
18	3.02	2.59	64.80	12.16	7.90	2.51	23079.32	162.28
19	3.53	1.96	66.31	10.83	8.06	2.61	23374.81	163.46
20	3.74	2.61	64.44	10.46	8.25	2.67	22846.97	162.38
21	5.50	2.82	66.24	11.03	8.15	2.91	22816.68	163.43
22	5.65	2.96	67.29	12.27	8.43	3.33	22466.45	161.32
23	6.82	3.17	66.25	11.40	8.88	3.54	21761.18	160.74
24	7.91	2.41	64.97	9.57	8.13	3.58	22722.51	163.41
25	8.12	2.12	66.30	11.09	8.44	3.66	22296.87	161.77
26	8.88	1.97	66.41	10.48	8.50	3.71	22483.89	161.16
27	11.84	2.28	66.18	9.67	8.16	3.73	22531.72	159.32
28	11.41	2.77	64.38	9.42	7.96	3.84	23501.64	163.25
29	11.28	2.46	67.67	10.09	8.51	3.92	22865.88	162.70
30	6.29	2.65	57.96	10.18	8.15	3.28	23056.30	163.35
31	3.04	4.68	58.07	10.40	8.19	2.32	23524.81	165.17
平均值	8.04	2.85	64.73	10.11	8.17	3.25	23021.71	162.16
最大值	12.54	5.40	67.67	16.76	8.88	3.92	23692.30	165.17
最小值	1.05	1.56	57.96	6.61	7.67	2.32	21761.18	157.84
排放標準	<60.00	<150.00	<85.00	<150.00		<10.00		
月排放量	225.54	60.92	2269.02	493.63				