

嘉義市垃圾焚化廠CEMS煙囪監測系統月報

資料日期 114年11月

文件編號

煙囪編號:

P001

測項	氯化氫	一氧化碳	氮氧化物	二氧化硫	氧氣	不透光率	流速/流率	溫度
日/單位	ppm	ppm	ppm	ppm	%	%	m3/hr	°C
01	10.47	1.71	64.73	8.94	7.26	2.46	24065.62	156.77
02	11.14	1.70	64.15	9.11	7.18	2.45	24242.76	155.11
03	10.39	1.71	63.68	7.67	7.08	2.46	24167.05	156.85
04	9.45	1.61	63.36	7.63	7.00	2.46	24386.88	158.36
05	10.75	1.92	63.28	9.33	7.08	2.45	24326.28	155.40
06	9.55	1.74	63.33	7.90	6.95	2.46	24590.67	157.54
07	9.86	1.82	63.91	7.38	7.13	2.46	24408.45	158.45
08	10.90	1.70	64.29	8.93	7.20	2.46	24374.95	157.91
09	9.62	1.75	64.11	8.30	7.15	2.45	24670.27	158.10
10	10.66	1.69	63.87	8.56	6.93	2.43	24755.57	159.07
11	11.16	1.73	63.80	8.96	7.07	2.38	24601.03	159.19
12	11.15	1.77	63.68	8.09	6.95	2.37	24899.20	155.73
13	10.50	1.73	63.85	8.16	6.96	2.38	24695.22	157.56
14	11.42	1.71	64.02	6.70	6.91	2.39	24949.69	156.64
15	10.66	1.73	64.70	7.76	7.07	2.39	24377.05	157.11
16	11.94	1.70	64.13	7.02	6.94	2.39	24717.70	156.95
17	11.00	1.77	64.57	6.58	7.15	2.39	24359.45	160.95
18	10.00	1.73	65.35	6.41	6.91	2.41	24857.67	158.75
19	10.91	1.69	66.17	8.25	7.08	2.32	24392.53	155.73
20	6.32	1.80	66.60	8.74	7.19	2.20	24121.57	157.67
21	7.10	1.78	66.37	7.68	7.32	2.21	23904.96	159.45
22	8.98	1.69	67.04	7.52	7.27	2.22	23856.80	159.75
23	8.63	1.73	66.71	7.35	7.15	2.26	23954.58	162.41
24	8.44	1.75	66.68	5.87	7.60	2.26	23376.04	161.21
25	7.78	3.51	66.70	6.29	7.71	2.25	23320.91	160.73
26	8.58	1.93	64.82	7.73	7.04	2.22	24424.98	155.53
27	10.56	1.85	64.81	8.68	6.92	2.24	24227.32	156.70
28	8.55	1.67	66.39	7.15	7.12	2.24	24070.42	157.32
29	10.08	2.93	66.12	8.74	7.15	2.22	24045.59	153.85
30	10.05	1.87	64.88	8.42	6.74	2.23	24703.38	155.14
31								
平均值	9.89	1.85	64.87	7.86	7.11	2.35	24328.15	157.73
最大值	11.94	3.51	67.04	9.33	7.71	2.46	24949.69	162.41
最小值	6.32	1.61	63.28	5.87	6.74	2.20	23320.91	153.85
排放標準	<60.00	<150.00	<85.00	<150.00		<10.00		
月排放量	283.77	40.56	2329.89	394.86				