

嘉義市垃圾焚化廠CEMS煙囪監測系統月報

資料日期 114年11月

文件編號

煙囪編號:

P002

測項	氯化氫	一氧化碳	氮氧化物	二氧化硫	氧氣	不透光率	流速/流率	溫度
日/單位	ppm	ppm	ppm	ppm	%	%	m3/hr	°C
01	1.90	6.20	65.81	10.28	8.20	2.42	22915.23	163.80
02	5.50	4.96	66.69	6.22	8.59	2.50	22063.67	163.44
03	5.29	5.24	66.76	6.00	8.90	2.57	21621.69	165.36
04	5.41	3.72	66.98	3.89	8.35	2.65	22306.55	164.48
05	8.45	3.84	67.73	6.74	8.25	2.76	22556.41	163.40
06	8.31	3.86	68.57	4.05	8.61	2.89	22301.28	163.89
07	5.39	4.66	66.43	3.72	8.83	2.94	22104.60	165.42
08	6.94	4.32	67.31	3.76	8.52	3.00	22232.47	163.53
09	6.09	4.24	65.51	4.87	8.56	3.10	22323.95	164.56
10	6.94	3.93	66.76	4.43	8.54	3.15	22347.36	163.42
11	6.27	3.95	66.82	4.30	8.65	3.27	22524.00	164.89
12	8.07	3.60	67.56	4.24	8.56	3.27	22474.16	164.18
13	8.46	3.98	66.20	4.67	8.56	3.37	22156.33	165.21
14	7.31	3.71	68.25	2.38	8.47	3.46	22665.98	167.87
15	7.59	4.20	68.15	4.38	8.75	3.55	22182.32	163.58
16	4.30	3.54	67.09	3.55	8.53	3.61	22622.73	164.65
17	6.03	3.79	66.74	3.12	8.30	3.69	23030.19	167.76
18	6.01	3.68	67.01	2.49	8.31	3.73	22969.07	166.48
19	4.30	4.83	65.50	4.36	8.61	3.14	22967.64	166.96
20	4.34	3.46	67.99	5.27	8.71	2.18	22056.14	165.66
21	6.07	4.23	67.75	4.38	8.94	2.35	22235.55	168.61
22	6.31	4.06	68.73	2.18	8.81	2.43	22292.56	166.89
23	5.64	3.72	68.00	2.82	8.73	2.48	22418.94	167.99
24	8.18	3.14	67.09	1.72	8.64	2.57	22381.76	165.24
25	7.45	3.78	68.37	3.65	8.45	2.69	22656.57	165.18
26	7.52	5.02	67.43	6.48	8.31	2.96	22914.21	165.71
27	5.89	3.69	68.78	5.17	8.20	3.07	22938.17	165.20
28	5.63	3.86	67.77	5.54	8.30	3.19	22828.98	165.15
29	10.39	4.39	66.98	8.19	8.48	3.29	22074.19	162.76
30	9.90	3.55	66.40	6.43	8.01	3.37	22821.24	162.82
31								
平均值	6.53	4.11	67.24	4.64	8.52	2.99	22466.13	165.14
最大值	10.39	6.20	68.78	10.28	8.94	3.73	23030.19	168.61
最小值	1.90	3.14	65.50	1.72	8.01	2.18	21621.69	162.76
排放標準	<60.00	<150.00	<85.00	<150.00		<10.00		
月排放量	172.32	82.92	2229.85	215.29				