

嘉義市垃圾焚化廠CEMS煙囪監測系統月報

資料日期 114年12月

文件編號

煙囪編號:

P001

測項	氯化氫	一氧化碳	氮氧化物	二氧化硫	氧氣	不透光率	流速/流率	溫度
日/單位	ppm	ppm	ppm	ppm	%	%	m3/hr	°C
01	10.71	1.51	65.96	7.47	6.92	2.22	24380.26	155.60
02	9.40	1.56	66.15	6.84	6.99	2.22	24220.25	160.22
03	11.33	1.67	66.49	8.75	7.28	2.21	23915.74	154.85
04	9.97	1.81	66.48	8.33	7.08	2.23	24078.63	157.82
05	9.22	2.03	67.42	8.08	7.46	2.21	23640.99	157.79
06	8.02	30.65	74.04	7.79	9.36	2.22	21982.88	154.80
07	10.54	1.77	66.27	8.90	7.33	2.23	23815.23	156.44
08	9.68	1.51	66.53	7.62	7.13	2.25	23997.45	157.85
09	8.72	1.54	65.48	7.82	7.10	2.28	23948.13	159.40
10	8.68	2.12	63.95	8.33	7.02	2.26	24178.66	158.50
11	11.56	2.66	65.50	9.97	7.76	2.23	23435.98	153.51
12	9.26	1.58	65.73	8.54	7.69	2.20	23547.52	155.45
13	9.92	1.94	65.37	8.73	7.66	2.20	23542.06	152.07
14	9.64	1.96	65.45	8.50	7.51	2.21	23663.93	153.54
15	9.41	1.72	65.15	8.11	7.56	2.20	23423.49	155.69
16	10.75	1.95	64.38	8.69	7.51	2.18	23506.34	155.99
17	9.48	2.21	64.58	10.31	7.58	2.17	23519.27	154.40
18	7.80	2.13	65.02	8.53	7.65	2.15	23423.01	156.84
19	9.21	2.22	65.50	7.60	7.59	2.20	23565.42	154.80
20	10.14	2.15	65.79	8.32	7.45	2.32	23757.93	154.60
21	9.27	1.76	65.76	9.71	7.40	2.43	23872.79	158.49
22	7.63	1.82	65.73	8.58	7.31	2.42	23912.20	157.58
23	8.56	1.95	64.95	8.73	7.30	2.39	23813.19	157.97
24	9.15	2.09	64.47	10.35	7.25	2.31	23885.29	155.82
25	8.43	1.84	65.16	8.44	7.25	2.37	23969.62	157.43
26	9.71	1.87	66.48	8.56	7.54	2.37	23755.80	158.44
27	9.49	2.01	66.06	10.07	7.56	2.24	23643.19	156.42
28	8.83	2.00	65.97	10.63	7.34	2.18	23965.77	156.14
29	9.01	1.89	65.84	9.84	7.29	2.46	24061.45	155.61
30	11.98	1.70	65.82	9.95	7.36	2.60	23917.06	158.69
31	10.80	1.82	65.89	8.91	7.46	2.89	23981.35	155.80
平均值	9.56	2.82	65.92	8.74	7.44	2.29	23752.29	156.40
最大值	11.98	30.65	74.04	10.63	9.36	2.89	24380.26	160.22
最小值	7.63	1.51	63.95	6.84	6.92	2.15	21982.88	152.07
排放標準	<60.00	<150.00	<85.00	<150.00		<10.00		
月排放量	275.89	55.26	2383.75	442.41				