

嘉義市垃圾焚化廠CEMS煙囪監測系統月報

資料日期 114年12月

文件編號

煙囪編號:

P002

測項	氯化氫	一氧化碳	氮氧化物	二氧化硫	氧氣	不透光率	流速/流率	溫度
日/單位	ppm	ppm	ppm	ppm	%	%	m3/hr	°C
01	9.41	3.68	65.01	6.61	7.92	3.42	22912.40	164.15
02	7.49	3.71	68.81	4.24	8.47	3.16	22890.30	166.78
03	10.14	4.49	67.57	5.74	8.41	2.37	22966.50	163.55
04	7.60	4.13	67.19	4.93	8.15	2.46	22737.59	163.61
05	6.85	4.19	67.34	5.50	8.30	2.54	22859.81	166.03
06	9.08	4.61	68.66	6.18	8.39	2.60	23028.15	166.99
07	7.98	3.60	67.95	6.34	8.36	2.63	22994.02	165.22
08	9.45	3.40	68.77	5.57	8.29	2.65	22906.34	164.70
09	7.43	3.86	68.27	4.78	8.19	2.69	23017.34	165.78
10	8.16	5.00	68.69	5.16	8.60	2.71	23059.28	165.40
11	9.08	4.20	66.52	7.02	8.47	2.73	22610.73	163.30
12	5.93	3.63	66.58	5.62	8.45	2.77	22682.76	165.69
13	8.59	3.73	66.77	7.01	8.42	2.76	22604.64	162.44
14	8.69	4.13	66.89	5.78	8.36	2.78	22504.25	163.65
15	7.46	2.89	67.26	6.55	8.44	2.84	22498.45	166.01
16	8.73	3.14	66.62	5.84	8.30	2.86	22659.80	165.64
17	10.02	3.66	67.52	7.51	8.33	2.90	22810.26	165.29
18	7.35	3.22	66.17	5.01	8.16	2.94	23048.48	167.90
19	6.91	3.55	66.10	4.39	8.32	2.70	23177.39	166.52
20	7.33	4.47	66.91	5.74	8.23	2.40	23165.39	164.35
21	8.78	3.41	66.42	6.86	8.00	2.41	23730.69	165.65
22	7.35	3.39	65.64	5.75	7.94	2.43	23608.92	165.68
23	9.08	3.08	66.03	7.50	7.85	2.47	23996.56	166.35
24	8.81	3.77	65.97	8.34	7.84	2.50	23839.05	164.21
25	8.74	3.49	67.13	7.07	8.10	2.50	23568.73	165.27
26	9.51	3.58	66.50	7.97	8.29	2.57	23681.73	165.75
27	7.22	3.52	65.39	9.72	8.04	2.59	23705.16	165.58
28	9.01	3.73	66.75	10.09	8.04	2.62	23590.28	165.40
29	10.59	3.32	68.01	7.93	8.23	2.65	23274.96	164.10
30	9.66	3.62	68.26	7.43	8.21	2.68	23947.31	166.61
31	11.12	3.42	67.43	9.47	8.12	2.71	23909.78	165.60
平均值	8.50	3.73	67.07	6.57	8.23	2.68	23160.87	165.26
最大值	11.12	5.00	68.81	10.09	8.60	3.42	23996.56	167.90
最小值	5.93	2.89	65.01	4.24	7.84	2.37	22498.45	162.44
排放標準	<60.00	<150.00	<85.00	<150.00		<10.00		
月排放量	239.15	80.10	2365.91	324.22				