

# 嘉義市垃圾焚化廠CEMS煙囪監測系統月報

資料日期 115年1月

文件編號

煙囪編號:

P001

測項	氯化氫	一氧化碳	氮氧化物	二氧化硫	氧氣	不透光率	流速/流率	溫度
日/單位	ppm	ppm	ppm	ppm	%	%	m3/hr	°C
01	11.27	2.02	64.54	8.79	7.23	3.03	24133.49	158.13
02	9.93	1.66	64.64	7.76	7.19	3.01	24021.25	156.89
03	10.77	2.04	66.10	7.00	7.53	2.97	23508.49	156.18
04	12.03	1.87	64.89	8.68	7.66	2.98	23506.49	156.64
05	10.99	1.72	65.16	8.81	7.57	2.33	23589.84	154.36
06	10.85	1.79	66.10	7.96	7.57	1.93	23370.11	154.65
07	10.26	2.12	66.03	6.95	7.57	1.89	23497.23	153.52
08	12.50	1.74	67.02	7.75	7.57	1.90	23451.09	154.28
09	9.70	1.81	65.64	8.55	7.62	1.89	23367.16	156.76
10	8.63	1.98	66.98	10.59	7.59	1.94	23404.28	155.96
11	10.55	2.08	65.76	8.60	7.42	2.01	23503.59	157.23
12	11.16	1.73	65.20	8.21	7.22	2.00	23850.73	158.04
13	11.27	1.63	65.65	8.71	7.38	2.01	23775.44	157.60
14	11.61	1.78	65.28	10.10	7.31	1.98	23882.69	154.78
15	10.04	1.65	66.91	12.36	7.81	2.07	23155.13	155.81
16	7.50	1.73	65.42	12.13	7.65	2.05	23409.32	156.45
17	6.44	1.91	65.17	11.04	7.56	2.14	23625.18	152.81
18	8.39	2.05	65.79	11.28	7.61	2.20	23661.22	151.11
19	7.28	1.92	64.50	12.13	7.42	1.93	23895.26	152.23
20	8.85	1.73	63.75	9.28	7.48	1.58	23771.24	152.65
21	7.70	2.28	64.06	5.83	7.44	1.56	23718.78	151.61
22	8.67	1.85	63.97	6.11	7.27	1.58	23905.20	152.90
23	9.43	2.16	65.13	5.73	7.56	1.57	23653.97	154.44
24	8.16	2.05	64.35	6.80	7.31	1.65	23788.20	154.78
25	8.90	1.79	64.80	5.75	7.38	1.81	23771.80	155.58
26	6.35	1.99	66.50	4.22	7.83	1.96	23338.41	155.71
27	5.73	1.68	64.16	3.27	7.44	2.10	23630.73	156.30
28	7.60	2.55	63.61	5.10	7.17	2.16	24020.14	151.90
29	8.88	2.10	62.80	4.97	7.12	2.20	24175.47	150.69
30	8.44	2.02	64.74	2.98	7.56	2.24	23616.72	150.47
31	9.74	2.30	65.51	3.60	7.76	2.33	23379.81	146.57
平均值	9.34	1.93	65.17	7.78	7.48	2.10	23657.37	154.42
最大值	12.50	2.55	67.02	12.36	7.83	3.03	24175.47	158.13
最小值	5.73	1.63	62.80	2.98	7.12	1.56	23155.13	146.57
排放標準	<60.00	<150.00	<85.00	<150.00		<10.00		
月排放量	267.81	42.46	2349.62	390.85				