

嘉義市垃圾焚化廠CEMS煙囪監測系統月報

資料日期 115年1月

文件編號

煙囪編號:

P002

測項	氯化氫	一氧化碳	氮氧化物	二氧化硫	氧氣	不透光率	流速/流率	溫度
日/單位	ppm	ppm	ppm	ppm	%	%	m3/hr	°C
01	10.41	3.35	67.19	6.98	8.23	2.72	23724.20	167.95
02	9.73	3.75	67.73	6.11	8.53	2.73	23369.00	166.38
03	11.15	3.96	67.76	6.05	8.75	2.79	22918.53	166.47
04	9.89	3.63	65.45	7.52	8.54	2.81	23352.58	165.97
05	12.13	3.12	63.47	7.27	8.12	2.25	23626.90	165.62
06	9.40	3.64	64.71	7.79	8.42	1.84	22799.71	162.87
07	10.71	3.58	66.89	8.71	8.62	1.87	22602.31	165.07
08	10.21	3.62	66.23	6.96	8.73	1.92	22577.94	167.50
09	9.44	3.82	68.42	7.24	9.03	1.98	22192.93	167.80
10	9.59	3.99	69.18	8.99	9.18	2.00	21989.27	164.25
11	6.18	3.48	66.11	7.84	8.90	2.03	21990.06	166.11
12	5.98	3.77	66.69	7.20	9.15	2.07	21727.78	168.47
13	8.51	5.13	66.34	7.86	9.21	2.10	21735.44	168.27
14	11.69	3.60	67.39	8.25	9.07	2.15	20233.17	162.47
15	7.35	3.03	65.62	11.08	8.27	2.19	23284.02	163.13
16	11.11	3.28	65.68	8.27	8.80	2.23	21940.29	163.05
17	13.49	3.32	66.16	8.19	8.45	2.29	22126.81	161.64
18	12.48	3.57	65.88	7.78	8.78	2.32	22028.60	161.85
19	8.13	4.39	67.80	9.10	9.10	2.19	21404.27	161.53
20	8.34	5.41	67.53	9.59	8.80	2.03	21993.78	162.56
21	12.07	4.35	66.84	8.03	8.67	2.05	22029.80	161.66
22	12.98	4.19	67.92	6.47	8.80	2.10	21954.69	163.90
23	13.99	4.66	65.84	6.07	9.18	2.14	21871.26	164.36
24	13.01	4.72	69.56	4.15	9.25	2.17	21492.48	163.47
25	12.78	3.50	68.49	3.34	9.05	2.20	21731.06	162.66
26	9.71	3.50	68.23	1.11	8.99	2.26	21680.23	164.73
27	9.97	3.66	66.93	1.59	9.24	2.30	21291.27	163.18
28	11.47	5.28	69.06	3.23	9.60	2.32	21054.31	159.61
29	13.00	3.77	68.56	2.56	9.84	2.35	20594.68	157.35
30	11.55	3.12	67.34	0.30	9.62	2.36	21113.77	158.37
31	13.15	3.05	67.34	0.80	9.54	2.37	20905.98	154.98
平均值	10.63	3.85	67.04	6.34	8.92	2.23	22043.13	163.65
最大值	13.99	5.41	69.56	11.08	9.84	2.81	23724.20	168.47
最小值	5.98	3.03	63.47	0.30	8.12	1.84	20233.17	154.98
排放標準	<60.00	<150.00	<85.00	<150.00		<10.00		
月排放量	283.88	78.77	2256.59	300.80				